

REFERENCES

1. Linnhoff, B., et al., A User Guide on Process Integration for the Efficient Use of Energy, IChem, Warwick Printing Co. Ltd., England, 1984.
2. Ishida, M. and Zheng, D. (1987), Energy Integration and System Synthesis, Tech. Promotion Assoc. Seminar, Bangkok, Thailand.
3. James M. Douglas, Conceptual Design of Chemical Process, pp. 216-288, McGraw-Hill Book Co., Inc., Singapore, 1st ed., 1988.
4. John E. Ahern, The Exergy Method of Energy Systems Analysis, John Willey & Sons, Inc., 1980.
5. Michael J. Moran, Availability Analysis : A Guide to Efficient Energy Use, Prentice-Hall, Inc., New Jersey, 1982.
6. Max S. Peters, Klaus D. Timmerhaus, Plant Design and Economics for Chemical Engineers, Chapter 5, McGraw-Hill Book Co., Inc., 3rd ed., 1981.
7. Gael D. Ulrich, A Guide to Chemical Engineering Process Design and Economics, Chapter 4-6, John Wiley & Sons, Inc., 1984.
8. Arthur P. Fraas, M. Necati Ozisik, Heat Exchanger Design, pp. 371-380, John Wiley & Sons, Inc., 1965.
9. Maxwell, J. B., Data Book on Hydrocarbons, Van Nostrand Reinhold, New York, 1950.
10. C.P. Kothandaraman, S. Subramanyan, Heat and Mass Transfer Data Book, 4th ed., John Wiley & Sons, Inc., 1989.
11. Perry, J.C., ed., Chemical Engineers' Handbook, 6th ed., McGraw-Hill Book Co., Inc., 1985.


12. W.L. Nelson, Petroleum Refinery Engineering, 4th ed., McGraw-Hill Book Co., Inc., 1987.
13. Robert C. Reid, John M. Prausnitz, Bruce E. Poling, The Properties of Gases & Liquids, 4th ed., McGraw-Hill Book Co., Inc., 1988.
14. Linnhoff, B., and John R. Flower, "Synthesis of Heat Exchanger Networks : (2 parts)", AICHE, Vol 24, No.4, pp. 633-654, 1978.
15. Linnhoff, B., Davis R. Mason, and Ian Wardle, "Understanding Heat Exchanger Networks", Computer & Chem.Eng., 3, pp. 295-302, 1979.
16. Linnhoff, B., and John A. Turner, "Heat -Recovery Networks : New Insight Yield Big Savings", Chem. Eng., pp. 56-70, Nov., 1981.
17. Linnhoff, B., and Don R. Vredeld, "Pinch Technology Has Come of Age", Chem. Eng. Prog., pp. 13-20, July, 1983.
18. Linnhoff, B., G.T. Polley, "General Process Improvements through Pinch Technology", Chem. Eng. Prog., pp 51-58, June, 1988.
19. Tjaan N. Tjoe, Linnhoff, B., "Using Pinch Technology for Process Retrofit", Chemical Engineering, pp. 10, 1986.
20. Umeda T., Itoh J., Shiriko K., "Heat Exchanger System Synthesis, CEP, July, pp. 70-76, 1978.
21. Doldan O.B., Bagajewicz M.J., Cerda J., "Designing Heat Exchanger Networks for Existing Chemical Plants", Comput. Chem. Engng., 9 (5), pp. 483-489, 1985.
22. Floudas C.A., Grossmann I.E., "Automatic Generation of Multiperiod Heat Exchanger Network Configurations", Comput. Chem. Engng., 11 (2), pp. 123-142, 1987.


23. Umeda T., Niida K., Shiroko K., "A Thermodynamic Approach to Heat Integration in Distillation Systems", AICHE., 25 (3), 423-429, 1979.
24. Calandranis J., Stephanopoulos G., "Structural Operability Analysis of Heat Exchanger Networks", Chem. Eng. Res. Des., 64, September, 347-364, 1986.
25. Linnhoff B., Witherell W.D., "Pinch Technology Guide Retrofit", Oil and Gas Journal, April 7, pp. 54-65, 1986.
26. Alan O., "Experiences in Process Integration", The Chemical Engineer., May, pp. 56-59, 1986.
27. D. W. Townsend, "Second Law Analysis in Practice", The Chemical Engineer, October, pp. 628-633, 1980.
28. Thane R. Brown, "Use these Guidelines for Quick Preliminary Selection of Heat-exchanger Type", Chemical Engineering, February, 1986.
29. Richard Turton, Dean Ferguson, Octave Levenspiel, "Charts for the Performance and Design of Heat Exchangers", Chemical Engineering, August, 1986.
30. วิชาญ กัณหาพิทักษ์กุล, สุพจน์ เกตุโคตรประการ, ชัยยศ วรวิทย์อุคตมสุข (1988).
"Pinch เทคโนโลยีและโปรแกรมวิเคราะห์คอมพิวเตอร์เพื่อหาจุดที่ต่ำสุดของโรงงาน", เทคโนโลยี, 79, 50.
31. วิชาญ กัณหาพิทักษ์กุล, เทคนิคการประหยัดพลังงาน ภาคความร้อน, สมาคมส่งเสริมเทคโนโลยี (ไทย-ญี่ปุ่น), 2525, หน้า 51.


Appendix A


Computer Program Flow Chart


A) Main Program
















B) Subprogram SORTZ(X,J)



C) Subprogram SORTA(Y,J,ORDER)



Appendix B

List of Energy Targeting Program

```
C=====
C
C                               THESIS PROGRAM
C=====
C
C           THE PROGRAM WAS DEVELOPED TO EVALUATE MINIMUM
C UTILITY REQUIREMENTS AND PINCH POINT TEMPERATURE FOR
C THE MINIMUM ENERGY RECOVERY (MER) DESIGN.
C
C***** DEFINE VARIABLES AND ASSIGN DIMENSIONS *****
C234567890
REAL TSH(10),TTH(10)
REAL TSC(10),TTC(10)
REAL TH(20),TC(20),T(30),THI(30)
REAL CPH(10),ENTH(30)
REAL CPC(10),ENTC(30)
REAL ENTP(30),ACC(30)
REAL ACCSORTA(30),HTFLOW(30)
INTEGER IH,IC,NUM,NUMH,NUMC,M,L,K
INTEGER INTV(30),ITEMP
C
C***** START TO RUN THE PROGRAM *****
WRITE(*,101)
101 FORMAT(/1X,'INPUT THE FOLLOWING DATA')
WRITE(*,102)
102 FORMAT(/1X,'NO. OF HOT STREAMS = ')
READ(*,001)IH
001 FORMAT(I4)
WRITE(*,103)
103 FORMAT(/1X,'NO. OF COLD STREAMS = ')
READ(*,001)IC
WRITE(*,104)
104 FORMAT(/1X,'INPUT TEMPERATURES IN UNIT OF (oF) or (oC) ',
*//3X,'IF TEMPERATURE UNIT IS oF : KEY 1',
*//3X,'IF TEMPERATURE UNIT IS oC : KEY 2')
READ(*,001)ITEMP
C
C***** TEMPERATURE UNIT IN oF *****
IF(ITEMP.EQ.1) THEN
C
C***** INPUT HOT STREAM DATA *****
WRITE(*,105)
105 FORMAT(/6X,'HOT-STREAM DATA : ',/)
DO 110 I=1,IH
WRITE(*,106)I
106 FORMAT(2X,'HOT STREAM No.',I2)
WRITE(*,107)
107 FORMAT(2X,'SUPPLY TEMPERATURE (oF) = ')
READ(*,002)TSH(I)
```



```

002 FORMAT(F8.2)
WRITE(*,108)
108 FORMAT(2X,'TARGET TEMPERATURE (oF) = ')
READ(*,002)TTH(I)
WRITE(*,109)
109 FORMAT(2X,'HEAT CAPACITY FLOWRATE (BTU/hr-F)')
READ(*,002)CPH(I)
WRITE(*,003)
003 FORMAT(' ')
110 CONTINUE

```

C

```

C***** INPUT COLD STREAM DATA *****

```

```

WRITE(*,111)
111 FORMAT(/6X,'COLD-STREAM DATA : ',/)
DO 116 I=1,IC
WRITE(*,112)I
112 FORMAT(2X,'COLD STREAM No.',I2)
WRITE(*,113)
113 FORMAT(2X,'SUPPLY TEMPERATURE (oF) = ')
READ(*,002)TSC(I)
WRITE(*,114)
114 FORMAT(2X,'TARGET TEMPERATURE (oF) = ')
READ(*,002)TTC(I)
WRITE(*,115)
115 FORMAT(2X,'HEAT CAPACITY FLOWRATE (BTU/hr-F) = ')
READ(*,002)CPC(I)
WRITE(*,003)
116 CONTINUE

```

C

```

C***** SPECIFY MINIMUM TEMPERATURE DIFFERENCE *****

```

```

WRITE(*,117)
117 FORMAT(2X,'MINIMUM TEMPERATURE DIFFERENCE (oF) = ')
READ(*,002)DTMIN

```

C

```

C***** TEMPERATURE UNIT IN oC *****
ELSE

```

C

```

C***** INPUT HOT STREAM DATA *****

```

```

WRITE(*,118)
118 FORMAT(/6X,'HOT-STREAM DATA : ',/)
DO 123 I=1,IH
WRITE(*,119)I
119 FORMAT(2X,'HOT STREAM No.',I2)
WRITE(*,120)
120 FORMAT(2X,'SUPPLY TEMPERATURE (oC) = ')
READ(*,002)TSH(I)
WRITE(*,121)
121 FORMAT(2X,'TARGET TEMPERATURE (oC) = ')
READ(*,002)TTH(I)
WRITE(*,122)
122 FORMAT(2X,'HEAT CAPACITY FLOWRATE (kW/oC) = ')
READ(*,002)CPH(I)
WRITE(*,003)
123 CONTINUE

```

C

```

C***** INPUT COLD STREAM DATA *****
WRITE(*,124)
124 FORMAT(/6X,'COLD-STREAM DATA : ',/)
DO 129 I=1,IC
WRITE(*,125)I
125 FORMAT(2X,'COLD STREAM No. ',I2)
WRITE(*,126)
126 FORMAT(2X,'SUPPLY TEMPERATURE (oC) = ')
READ(*,002)TSC(I)
WRITE(*,127)
127 FORMAT(2X,'TARGET TEMPERATURE (oC) = ')
READ(*,002)TTC(I)
WRITE(*,128)
128 FORMAT(2X,'HEAT CAPACITY FLOWRATE (kW/oC) = ')
READ(*,002)CPC(I)
WRITE(*,003)
129 CONTINUE

C
C***** SPECIFY MINIMUM TEMPERATURE DIFFERENCE *****
WRITE(*,130)
130 FORMAT(2X,'MINIMUM TEMPERATURE DIFFERENCE (oC) = ')
READ(*,002)DTMIN
END IF

C
C***** PRINT OUT HOT-STREAM DATA *****
WRITE(*,131)
131 FORMAT('0',//T34,'HOT-STREAM DATA',/)
WRITE(*,132)
132 FORMAT(T8,'-----',OX,
* '-----')
WRITE(*,133)
133 FORMAT(T8,'HOT STREAM',T23,'SUPPLY TEMP.',T39,
* 'TARGET TEMP.',T54,'HEAT CAPACITY')
WRITE(*,134)
134 FORMAT(T12,'No.',T56,'FLOWRATE')
WRITE(*,132)
DO 136 I=1,IH
WRITE(*,135)I,TSH(I),TTH(I),CPH(I)
135 FORMAT(T11,I3,T23,F8.2,T40,F8.2,T55,F8.2)
136 CONTINUE
WRITE(*,003)
WRITE(*,132)

C
C***** PRINT OUT COLD-STREAM DATA *****
WRITE(*,137)
137 FORMAT('0',//T33,'COLD-STREAM DATA',/)
WRITE(*,132)
WRITE(*,138)
138 FORMAT(T8,'COLD STREAM',T23,'SUPPLY TEMP.',T39,
* 'TARGET TEMP.',T54,'HEAT CAPACITY')
WRITE(*,134)
WRITE(*,132)
DO 140 I=1,IC
WRITE(*,139)I,TSC(I),TTC(I),CPC(I)
139 FORMAT(T11,I3,T23,F8.2,T40,F8.2,T55,F8.2)
140 CONTINUE

```




```
WRITE(*,003)
WRITE(*,132)
WRITE(*,141)DTMIN
141 FORMAT('0',/20X,'MINIMUM TEMPERATURE DIFFERENCE =',F8.2)
C
C***** RESET TEMPERATURES TO THE SAME VARIABLE *****
DO 142 I = 1,IH
T(I) = TSH(I)
T(IH+I) = TTH(I)
142 CONTINUE
DO 143 I = 1,IC
T(2*IH+I) = TSC(I)
T(2*IH+IC+I) = TTC(I)
143 CONTINUE
NUM = 2*IH+IC+I-1
C
C***** SORT ALL TEMPERATURES *****
CALL SORTZ(T,NUM)
C
C***** SORT HOT TEMPERATURES *****
DO 144 I = 1,IH
TH(I) = TSH(I)
TH(IH+I) = TTH(I)
144 CONTINUE
NUMH = IH+I-1
CALL SORTA (TH,NUMH,INTV)
C
C***** SORT COLD TEMPERATURES *****
DO 145 I = 1,IC
TC(I) = TSC(I)
TC(IC+I) = TTC(I)
145 CONTINUE
NUMC = IC+I-1
CALL SORTA (TC,NUMC,INTV)
C
C***** SORT TEMPERATURE INTERVALS *****
M = 0
DO 148 I = 1,NUM
IF (T(I).EQ.T(I+1))GO TO 148
C
C***** CHECK IF ANY T(I) EQUAL TO ANY STARTING OR TARGET ****
C TEMPERATURE OF HOT STREAM
THX = 0
DO 146 J = 1;NUMH
IF (T(I)-TH(J).EQ.0) THX = T(I)
146 CONTINUE
C
C***** CHECK IF ANY T(I) EQUAL TO ANY STARTING OR TARGET ****
C TEMPERATURE OF COLD STREAM
TCX = 0
DO 147 K = 1,NUMC
IF (T(I)-TC(K).EQ.0) TCX = T(I)
147 CONTINUE
C
C***** FIND TEMPERATURE INTERVAL FOR EACH SUB NETWORK *****
IF (T(I).EQ. TCX) THEN
```

```

      M = M+1
      THI(M) = T(I)+DTMIN
    END IF
    IF (T(I).EQ. THX) THEN
      M = M+1
      THI(M) = T(I)
    END IF
148 CONTINUE
    CALL SORTZ (THI,M)
  C
  C***** DELETE THE ITERATED TEMPERATURES *****
    THI(M+1) = 10000
    K=0
    DO 149 I=1,M
      IF (THI(I) .EQ. THI(I+1)) GOTO 149
      K = K+1
      THI(K) = THI(I)
149 CONTINUE
    CALL SORTZ(THI,K)
  C
  C***** CALCULATE DEFICIENT HEAT IN EACH SUBNETWORK *****
    L = K-1
    DO 152 I=1,L
  C
  C***** CALCULATE HEAT REQUIREMENT FOR COLD STREAM *****
    DO 150 J=1,IC
      IF ((TTC(J)+DTMIN.GE.TH(I)).AND.(TSC(J)+DTMIN.LE.TH(I+1)))
        *ENTC(I) = CPC(J)*(TH(I)-TH(I+1))+ENTC(I)
150 CONTINUE
  C
  C***** CALCULATE EXCESS HEAT FROM HOT STREAM *****
    DO 151 N=1,IH
      IF ((TSH(N).GE.TH(I)).AND.(TTH(N).LE.TH(I+1)))
        *ENTH(I) = CPH(N)*(TH(I)-TH(I+1))+ENTH(I)
151 CONTINUE
      ENTP(I) = ENTC(I)-ENTH(I)
152 CONTINUE
  C
  C***** CALCULATE TOTAL ENTHALPY OUTPUT *****
    DO 153 I=1,L
      ACC(I) = ACC(I-1)-ENTP(I)
153 CONTINUE
  C
  C** CALCULATE MINIMUM VALUE OF ACC(I) AND PINCH TEMPERATURE **
    DO 154 I=1,L
      ACCSORTA(I) = ACC(I)
154 CONTINUE
      CALL SORTA(ACCSORTA,L,INTV)
      ACCMIN = ACCSORTA(1)
      HEAT = ABS(ACCMIN)
      DO 155 I=1,K
        HTFLOW(I) = ACC(I-1) + HEAT
155 CONTINUE
      IF(ACCMIN.LT.0) THEN
        CUMIN = HTFLOW(K)
        HUMIN = HEAT

```



```

ELSE
  CUMIN = ACC(L)
  HUMIN = 0
  END IF
  IF((CUMIN.EQ.0).OR.(HUMIN.EQ.0))THEN
    WRITE(*,156)
156 FORMAT('0',//T37,'CAUTION !')
    WRITE(*,157)
157 FORMAT(3X,/T14,'THIS PROGRAM IS THE THRESHOLD CASE.',2X,
  *'THE PROGRAM IS NOT',/T6,'DESIGNED FOR SOLVING IT.',2X,
  *'THE RESULT BELOW MIGHT BE INCORRECTED.',
  */T6,'PLEASE CHECK IT BY DRAWING COMPOSITE CURVE.')
    END IF
    THPINCH = THI(INTV(1)+1)
    TCPINCH = THPINCH-DTMIN
C
C***** PRINT OUT THE RESULT *****
  WRITE(*,158)
158 FORMAT('0',///T35,'RESULT',/)
  WRITE(*,159)
159 FORMAT(T7,'-----',OX,
  *'-----')
  WRITE(*,160)
160 FORMAT(T8,'INTERVAL',T19,'HOT - STREAM',T33,'DEFICIT',
  *T44,'CUMULATIVE',T58,'HEAT FLOW')
  WRITE(*,161)
161 FORMAT(T11,'No.',T19,'TEMPERATURE',T46,'OUTPUT')
  WRITE(*,159)
  DO 167 I=1,K
  IF (I.LE.K-1)THEN
    WRITE(*,163)THI(I),HTFLOW(I)
163 FORMAT(T20,F8.2,T58,F8.2)
    WRITE(*,164)I,ENTP(I),ACC(I)
164 FORMAT(T10,I3,T32,F8.2,T44,F8.2)
  ELSE
    WRITE(*,165)THI(K),HTFLOW(K)
165 FORMAT(T20,F8.2,T58,F8.2)
    WRITE(*,003)
    WRITE(*,159)
  END IF
167 CONTINUE
C
C***** CHECK UNIT OF THE RESULT *****
C
C***** TEMPERATURE UNIT IN oF *****
  IF(ITEMP.EQ.1) THEN
    WRITE(*,168)DTMIN
168 FORMAT(/10X,'MINIMUM TEMPERATURE DIFFERENCE      =',F8.2,
  *4X,'oF')
    WRITE(*,169)TCPINCH
169 FORMAT(10X,'PINCH IS LOCATED AT COLD TEMPERATURE  =',F8.2,
  *4X,'oF')
    WRITE(*,170)THPINCH
170 FORMAT(10X,'PINCH IS LOCATED AT HOT TEMPERATURE  =',F8.2,
  *4X,'oF',/)
    WRITE(*,171)

```

```

171 FORMAT('0',T8,'***** ENERGY TARGET ',OX,
* '*****')
WRITE(*,172)HUMIN
172 FORMAT(/10X,'MINIMUM HOT UTILITY REQUIREMENT      =',F8.2,
*4X,'BTU/hr')
WRITE(*,173)CUMIN
173 FORMAT(10X,'MINIMUM COLD UTILITY REQUIREMENET      =',F8.2,
*4X,'BTU/hr',/)

```

C

```

***** TEMPERATURE UNIT IN oC *****
ELSE
WRITE(*,174)DTMIN
174 FORMAT(/10X,'MINIMUM TEMPERATURE DIFFERENCE      =',F8.2,
*4X,'oC')
WRITE(*,175)TCPINCH
175 FORMAT(10X,'PINCH IS LOCATED AT COLD TEMPERATURE  =',F8.2,
*4X,'oC')
WRITE(*,176)THPINCH
176 FORMAT(10X,'PINCH IS LOCATED AT HOT TEMPERATURE   =',F8.2,
*4X,'oC',/)
WRITE(*,171)
WRITE(*,178)HUMIN
178 FORMAT(/10X,'MINIMUM HOT UTILITY REQUIREMENT      =',F8.2,
*4X,'kW')
WRITE(*,179)CUMIN
179 FORMAT(10X,'MINIMUM COLD UTILITY REQUIREMENET      =',F8.2,
*4X,'kW',/)
END IF
180 STOP
END

```

ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย

```

C
C
C***** SUBPROGRAM #1 : SORTING MAX TO MIN *****
C

```

```

SUBROUTINE SORTZ(X,J)
INTEGER J,A1,A2
REAL X(J),TEMP
100 IF (J .LE. 1) GOTO 101
200 DO 201 A1 = 1,J-1
300 DO 301 A2 = A1 + 1,J
400 IF (X(A1) .GE. X(A2)) GOTO 401
TEMP = X(A1)
X(A1) = X(A2)
X(A2) = TEMP
401 CONTINUE
301 CONTINUE
201 CONTINUE
101 CONTINUE
RETURN
END

```

```

C
C***** SUBPROGRAM #2 : SORTING MIN TO MAX *****
C

```

```

SUBROUTINE SORTA(Y,J,ORDER)
INTEGER J,A1,A2,ORDER(J),IP
REAL Y(J),PAT
100 IF (J .LE. 1) GOTO 101
DO 200 I=1,J
ORDER(I)=I
200 CONTINUE
300 DO 301 A1 = 1,J-1
400 DO 401 A2 = A1 + 1,J
500 IF (Y(A1) .LE. Y(A2)) GOTO 501
PAT = Y(A1)
Y(A1) = Y(A2)
Y(A2) = PAT
IP = ORDER(A1)
ORDER(A1) = ORDER(A2)
ORDER(A2) = IP
501 CONTINUE
401 CONTINUE
301 CONTINUE
101 CONTINUE
RETURN
END

```


Appendix C

Calculation Data

Table C.1 Direct fired heater data sheet
(F-1Q1 : Crude Heater)

UNIT PERFORMANCE			
1. FLUID CHARGE		CRUDE	STEAM
TOTAL FLUID	lb/hr	619,150	33,780
2. INLET FLOW			
VAPOR	lb/hr	0	33,780
LIQUID	lb/hr	619,150	0
MOL. WT. OF VAPOR			18
TEMPERATURE	°F	444	289
PRESSURE	PSIG	170	50
3. OUTLET FLOW			
VAPOR	lb/hr	391,300	33,780
LIQUID	lb/hr	227,850	0
MOL. WT. OF VAPOR		159.7	18
TEMPERATURE	°F	723	600
PRESSURE	PSIG	20	45
4. HEAT ABSORBED	MMBtu/hr	149.4	5.1
5. HEAT LIBERATED	MMBtu/hr	187.273 (OIL FIRED)	
6. THERMAL EFFICIENCY (LHV) %		82.5	(CALCULATED)
7. HEAT LOSS	%	1.5	(RADIANT&CONV.)
	%	16.0	(STACK)
8. FLUE GAS TEMPERATURE	°F	656	(LEAVING)
9. AIR TEMPERATURE	°F	77.0	
10. FUEL CHARACTERISTICS			
FLUE		15 oAPI CIL	
HEATING VALUE (LHV)	Btu/hr	17,500	
FLUE CONSUMPTION		10,623.6 (CALCULATED)	

Table C.2 : Heat exchanger specification sheet

NO.	EQUIPMENT	FLUID CIRCULATING	FLOW RATE IN-OUT (lb/hr)	TEMP. (°F)		°API	HEAT EXCHANGE (MBtu/hr)
				IN	OUT		
1	E-101	S.S. : CRUDE T.S. : LIGHT DISTILLATE	619,150 350,000	80 346	199 176	35.0 50.9	35.0
2	E-102	S.S. : CRUDE T.S. : KEROSENE	619,150 94,092	119 229	383 229	35.0 43.9	8.8
3	E-103	S.S. : CRUDE T.S. : DIESEL	619,150 98,029	229 272	510 272	35.0 34.3	14.4
4	E-104	S.S. : CRUDE T.S. : DIESEL CIR. REFLUX	619,150 134,000	272 540	310 390	35.0 35.3	58.5
5	E-105	S.S. : REDUCED CRUDE T.S. : CRUDE	241,040 619,150	697 345	310 452	15.3 35.0	56.4
6	E-403	S.S. : LIGHT NAPHTHA T.S. : DIESEL OIL	* 311,600 116,000	303 540	314 390	76.6 35.3	11.6
7	E-106	S.S. : FRACTIONATOR OVHD T.S. : WATER	* 476,540 5,605,000	252 115	187 60		89.2
8	E-107	S.S. : FRAC. OVHD PRODUCT T.S. : WATER	* 84,469 4,580,000	187 95	100 100		22.9
9	E-108	S.S. : HEAVY NAPHTHA T.S. : WATER	59,565 250,000	270 95	120 115	53.6	5.0
10	E-109	S.S. : KEROSENE T.S. : WATER	94,029 257,500	229 95	120 115	43.9	5.15
11	E-110	S.S. : DIESEL T.S. : WATER	98,029 393,000	272 95	120 115	34.3	7.86
12	E-111	S.S. : GAS OIL T.S. : WATER	50,245 730,000	611 95	120 115	27.3	14.6
13	E-112	S.S. : REDUCED CRUDE T.S. : WATER	241,040 1,130,000	364 95	180 115	15.3	22.6

Remark : * Light naphtha, fractionator overhead, and fractionator overhead product, respectively, circulated in shell side of exchanger No. E-403, E-106, and E-107 are two phase components. Their compositions are detailed in Table C.4.

- S.S. means shell side, and T.S. means tube side.

Table C.3 Phase compositions of E-403, E-106, E-107

NO.	EQUIPMENT	PHASE COMPOSITION	ENTERING			LEAVING		
			(lb/hr)		BUBLE OR DEW Pt. (°F)	(lb/hr)		BUBLE OR DEW Pt. (°F)
			VAPOR	LIQUID		VAPOR	LIQUID	
1	E-403	S.S. : LIGHT NAPHTHA	-	311,600	303	93,470	218,130	314.0
2	E-106	S.S. : H.C. : STREAM	442,760 33,780	- -	249 205	76,179 8,290	366,581 25,490	187.0 187.0
3	E-107	S.S. : H.C. : STREAM	76,179 8,290	- -	186 186	- -	76,179 8,290	108.0 108.0

Remark : - S.S. means shell side.

ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย



TABLE C.4 : MATERIAL BALANCE DATA

MB100-1

TOPPING UNIT : 100

DESIGN BASIS : 50,000 B/D

STREAM No.	1	2	3	4	5	6	7	8
COMPONENT	CRUDE CHARGE (LBS/HR)	STEAM TO TRANSFER LINE (LBS/HR)	STEAM TO RESIDUE STRIPPER (LBS/HR)	FRAC'TION REDUCED CRUDE (LBS/HR)	GAS OIL STRIPPER FEED (LBS/HR)	GAS OIL TO PLATED No. #3 (LBS/HR)	GAS OIL TO STORAGE (LBS/HR)	GAS OIL STRIPPER OVERHEAD (LBS/HR)
TOTAL H.C. STREAM WATER	619150 - -	- 16000 -	- 8953 -	241040 - -	60257 - -		50245 1333 -	10012
TOTAL	619150	16000	8953	241040	60257		50245	11345
MOLES/HR	2926	889	497	470	200		159	115
AVERAGE MW	211.6	18	18	512.9	301.3		316.0	98.7
API DEGREE	35.0	-	-	15.3	28.0		27.3	-
GMP @ TEMP	1475	-	-	518	180		132	-
BPSD	50,000	-	-	17156	4661		3863	-
SCFM	-	546	3140	-	-		-	726
MMSCFD	-	8.09	4.52	-	-		-	1.05

TABLE C.4 (CONTINUED)

TOPPING UNIT : 100

STREAM No.	9	10	11	12	13	14	15	16
COMPONENT	STEAM TO GAS OIL STRIPPER (LBS/HR)	FRAC'TION DIESEL DRAW (LBS/HR)	DIESEL CIRCULATED REFLUX (LBS/HR)	DIESEL CIRCULATED VS. CRUDE (LBS/HR)	DIESEL TO E-403 (LBS/HR)	DIESEL STRIPPER FEED (LBS/HR)	STEAM TO DIESEL STRIPPER (LBS/HR)	DIESEL STRIPPER OVERHEAD (LBS/HR)
TOTAL H.C. STREAM WATER	- 1333 -	372810 - -	250000 - -	134000 - -	116000 - -	122810 - -	- 2792 -	24781 2792 -
TOTAL	1333	372810	250000	134000	116000	122810	2792	27573
MOLES/HR	74	1609	1079	578	501	530	155	279
AVERAGE MW	18	231.7	231.7	231.7	231.7	231.7	18	98.8
API DEGREE	-	35.3	35.3	35.3	35.3	35.3	-	-
GMP @ TEMP	-	1148	770	413	357	378	979	1762
BPSD	-	30612	20226	10841	9385	9936	1.41	2.54
SCFM	467	-	-	-	-	-	-	-
MNSCFD	0.67	-	-	-	-	-	-	-

MB100-2

TABLE C.4 (CONTINUED)

TOPPING UNIT : 100

STREAM No.	17	18	19	20	21	22	23	24
COMPONENT	DIESEL FRAC'TION COALESCER (LBS/HR)	DIESEL FOR MIDDLE DISTILLATE (LBS/HR)	DIESEL TO BATTERY LIMIT (LBS/HR)	KEROSENE STRIPPER FEED (LBS/HR)	STEAM TO KEROSENE STRIPPER (LBS/HR)	KEROSENE STRIPPER OVERHEAD (LBS/HR)	KEROSENE TO COALESCER (LBS/HR)	KEROSENE TO MIDDLE DISTILLATE (LBS/HR)
TOTAL H.C. STREAM WATER	98029 - -	16172 - -	81857 - -	117428 - -	- 2792 -	23336 2792 -	94092 - -	15277 - -
TOTAL	98029	16172	81857	117428	2792	26128	94092	15277
MOLES/HR	406	67	339	694	155	309	540	88
AVERAGE MW	241.5	241.5	241.5	169.2	18	84.6	174.4	174.4
API DEGREE	34.3	34.3	34.3	44.8	-	-	43.9	43.9
GMP @ TEMP	236	39	197	368	-	-	241	39
BPSD	7880	1300	6580	10042	-	-	8007	1300
SCFM	-	-	-	-	979	1952	-	-
MMSCFD	-	-	-	-	1.41	2.81	-	-

MB100-3

TABLE C.4 (CONTINUED)

TOPPING UNIT : 100

STREAM No.	25	26	27	28	29	30	31	32
COMPONENT	KEROSENE TO BATTERY LIMIT (LBS/HR)	MIDDLE DISTILLATE TO BATTERY LIMIT (LBS/HR)	HEAVY NAPHTHA STRIPPER FEED (LBS/HR)	STEAM TO HEAVY NAPHTHA STRIPPER (LBS/HR)	HEAVY NAPHTHA STRIPPER OVERHEAD (LBS/HR)	HEAVY NAPHTHA TO PRETREATER (LBS/HR)	HEAVY NAPHTHA TO STORAGE (LBS/HR)	KEROSENE CIRCULATED REFLUX (LBS/HR)
TOTAL H.C. STREAM WATER	78815 - -	31449 - -	72407 - -	- 1910 -	12842 1910 -	59565 - -	NORMALLY NO FLOW	350000 - -
TOTAL	78815	31449	72407	1910	14752	59565		350000
MOLES/HR	452	155	572	106	216	462	DESIGN FOR (30)	2518
AVERAGE MW	174.4	202.9	126.6	18	68.3	128.9	AT 120 of	139.0
API DEGREE	43.9	39	54.4	-	-	53.6		50.9
GMP @ TEMP	202	78	223	-	-	178		1085
BPSD	6707	2600	6529	-	-	5348		30946
SCFM	-	-	-	670	1364	-		-
MMSCFD	-	-	-	0.96	1.96	-		-

MB100-4

TABLE C.4 (CONTINUED)

TOPPING UNIT : 100

STREIM No.	33	34	35	36	37	38	39	40	41
COMPONENT	FRICTION OR OVERHEAD (LBS/HR)	REFLUX CONDENSER OUTLET (LBS/HR)	REFLUX CONDENSE BYPASS (LBS/HR)	VAPOR FROM REFLUX DRUM (LBS/HR)	FRACTATOR REFLUX (LBS/HR)	REFLUX DRUM FOR WATER (LBS/HR)	OVERHEAD RECYCLE WATER (LBS/HR)	WILD LIGHT NAPHTHA (LBS/HR)	STEAM TO SUPER HEATED (LBS/HR)
METHANE								2	
ETHANE								25	
PROPANE								964	
ISOBUTANE								867	
N-BUTANE								5787	
LIGHT NAPHTHA								68534	
TOTAL H.C.	442760	442760	NORMALLY	76179	366581	-	-	76179	-
STREAM	33780	8290	NO	8290	-	-	-	-	33780
WATER	-	25490	FLOW	-	-	25490	8290	-	-
TOTAL	476540	476540		84469	366581	25490	8290	76179	33780
MOLES/HR	6266	6260	DESIGN	1349	3501	1416	460	889	1876
AVERAGE MW	76.1	MULTIPHASE	FOR	62.9	104.7	18	18	85.7	18
API DEGREE	-	SEE (36)	25 %	-	64.6	-	-	78.0	-
GMP @ TEMP	-	FOR VAPOR	STREAM	-	1118	53	17	231	-
BPSD	-	AND	(33)	-	34872	-	-	7746	-
SCFM	39582	(37)+(38)		8522	-	-	-	-	11851
MMSCFD	57.0	FOR L10		12.27	-	-	-	-	1706

MB100-5

Appendix D

Material and Energy Balance

D.1 Material and Energy Balance Around F-101

Data

1. Crude charge :

Input : liquid phase = 619,150 lb/hr, $T = 444\text{ }^{\circ}\text{F}$, $^{\circ}\text{API} = 35$

Output : liquid phase = 391,300 lb/hr, gas phase = 227,850 lb/hr
 $T = 723\text{ }^{\circ}\text{F}$, latent heat (at $T = 520\text{ }^{\circ}\text{F}$) is 105.8 Btu/lb

2. Steam :

Input : Saturated steam $T = 298\text{ }^{\circ}\text{F}$, $P = 64.7\text{ psia}$,
 Enthalpy = 1179.1 Btu/lb-F

Output : Superheated steam $T = 600\text{ }^{\circ}\text{F}$, $P = 59.7\text{ psia}$,
 Enthalpy = 1330.4 Btu/lb-F

3. Fuel oil :

Feed 10,623.6 lb/hr, $T = 200\text{ }^{\circ}\text{F}$,
 heating value (LHV) = 17,500 Btu/lb = 9697.7 kcal/kg fuel

4. Air :

$T = 80\text{ }^{\circ}\text{F}$, 25 % excess, density (at $0\text{ }^{\circ}\text{C}$) = 1.2928 kg/cu.m.

5. Flue gas :

$T = 656\text{ }^{\circ}\text{F}$, Cpm hot air ($T = 656\text{ to }80\text{ }^{\circ}\text{F}$) = 0.267 Btu/lb-F




Figure D.1 Material balance of crude heater

D1.1 Material Balance Around F-101

To determine the amount of air for combustion, we use Boie's Equation [31]

$$A_o = \frac{(12.38)(H_1 - 1100)}{10000} \quad \text{m}^3/\text{kg fuel}$$

$$A = mA_o \quad \text{m}^3/\text{kg fuel}$$

$$G_o = \frac{(15.75)(H_1 - 1100)}{10000} - 2.18 \quad \text{m}^3/\text{kg fuel}$$

$$G = G_o + (m-1)A_o \quad \text{m}^3/\text{kg fuel}$$

where

A_o = quantity of air theoretically required for complete combustion

A = quantity of air actually used for combustion

G_o = quantity of stack gas theoretically occurred

G = quantity of stack gas actually occurred

H_1 = low heating value of fuel (kcal/kg fuel)

m = air ratio (-)

Therefore,

$$A_o = \frac{(12.38)(9697.7 - 1100)}{10000} = 10.64 \quad \text{m}^3/\text{kg fuel}$$

$$A = 1.25(10.64) = 13.3 \quad \text{m}^3/\text{kg fuel}$$

Since, density of air (ρ) = 1.2928 kg/m³, therefore

$$A = \frac{13.3 \text{ m}^3}{\text{kg fuel}} \left| \frac{1.2928 \text{ kg air}}{\text{m}^3} \right. \\ = 17.20 \quad \text{kg/kg fuel (or lb/lb fuel)}$$

$$\text{Total air feed} = \frac{17.20 \text{ lb}}{\text{lb fuel}} * 10623.6 \text{ lb fuel}$$

$$= 182,732.58 \text{ lb air}$$

$$G_o = \frac{(15.75)(9697.7 - 1100)}{10000} - 2.18$$

$$= 11.3614 \quad \text{m}^3/\text{kg fuel}$$

$$\begin{aligned}
 G &= 11.3614 + (1.25-1)(10.64) \\
 &= 14.02 \quad \text{m}^3/\text{kg fuel} \\
 &= \frac{14.02 \text{ m}^3}{\text{kg fuel}} \left| \frac{1.2928 \text{ kg air}}{\text{m}^3} \right. \\
 &= 18.127 \quad \text{kg/kg fuel (or lb/lb fuel)} \\
 \text{Total stack gas} &= \frac{18.127 \text{ lb}}{\text{lb fuel}} * 10623.6 \text{ lb fuel} \\
 &= 192,572.26 \text{ lb air}
 \end{aligned}$$

Note that in the subsequent calculation, we will use the summation between weight of fuel oil feed and air feed ,i.e., 193,356.18 lb (182,732.58 + 10,623.6) as the weight of flue gas.

Overall Material Balance Around F-101

<u>Input</u>	<u>lb</u>
1. crude feed (liquid)	619,150.0
2. saturated steam feed	33,780.0
3. fuel oil feed	10,623.6
4. air feed	<u>182,732.6</u>
Total	<u>846,286.2</u>

<u>Output</u>	<u>lb</u>
1. heated crude (liquid)	391,300.0
(vapor)	227,850.0
2. superheated steam	33,780.0
4. dry flue gas	<u>193,356.2</u>
Total	<u>846,286.2</u>

Remark : Amount of water vapor entering as air humidity is subtracted from the amount of water vapor in the flue gas.

D1.2 Energy Balance Around F-101

1. Calculate Useful Heat to Hydrocarbon (H.C.) Crude

Temperature reference = 444 °F




Figure D.2 H.C. balance around F-101

1. Enthalpy of H.C. (liquid phase) : at T = 444 to 520 °F
(°API = 35 -- C_{pm} = 0.71 Btu/lb-°F)
$$H = 619,150(0.71)(520-444) = 33.41 \text{ MBtu/hr}$$
2. Enthalpy of H.C. (liquid phase) : at T = 520 to 723 °F
(°API = 42.5 -- C_{pm} = 0.74 Btu/lb-°F)
$$H = 391,300(0.74)(723-520) = 59.04 \text{ MBtu/hr}$$
3. Enthalpy of H.C. (gas phase) : at T = 520 to 723 °F
(C_{pm} = 0.67)
$$H = 227,850(0.67)(723-520) = 30.99 \text{ MBtu/hr}$$
4. Latent heat of H.C. (gas phase) : at T = 520 °F
$$H = 227,850(105.8) = 24.12 \text{ MBtu/hr}$$

The net heat absorbed by H.C. is 148.71 MBtu. Note that the calculated result above is extremely closed to the designed data (149.4 MBtu/hr) given in Table C.1, Appendix C.




Figure D.3 Enthalpy calculation diagram for H.C. balance


2. Calculate Useful Heat to Steam

Figure D.4 Steam balance around F-101

1. Enthalpy of saturated steam : at T = 298 °F, P = 64.7 psia

$$H = 1179.1(33780) = 39.83 \text{ MBtu/hr}$$
2. Enthalpy of superheated steam : at T = 600 °F, P = 59.7 psia

$$H = 1330.4(33780) = 44.94 \text{ MBtu/hr}$$

The net heat absorbed by steam is ,therefore,

$$Q = 44.94 - 39.83 = 5.11 \text{ MBtu/hr}$$

The calculated heat absorbed by steam above is equal to the design data (5.1 MBtu) given in Table C.1, Appendix C.

ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย



Overall Energy Balance Around F-101

Reference temperature is 80 °F

<u>Input</u>	<u>MBtu/hr</u>	<u>%</u>
1. Enthalpy of fuel oil		
a. sensible heat = $10623.6(0.43)(200-80) =$	0.54	0.28
b. heating value = $10623.6(17500) =$	185.91	99.71
2. Enthalpy of air (T = 80 °F)	= 0.00	0.00
Total	= <u>186.45</u>	<u>100.00</u>

<u>Output</u>	<u>MBtu/hr</u>	<u>%</u>
1. Useful heat to H.C.	= 148.71	79.76
2. Useful heat to steam	= 5.11	2.74
3. Heat to dry flue gas		
= $193356.18(0.267)(656-80) =$	29.74	16.0
4. Loss and radiation (by difference)	= 2.89	1.55
Total	= <u>186.45</u>	<u>100.00</u>

$$\text{Thermal efficiency} = \frac{(148.71 + 5.11) * 100}{186.45}$$

$$= 82.5 \%$$

จุฬาลงกรณ์มหาวิทยาลัย

Remark : Compared below are the results of the above calculation versus the design data taken from the direct fired heater data sheet, Table C.1, Appendix C. Little difference on each pair of comparison has been obtained. This means that the data received from the plant is quite accurate and reliable. .

		<u>Calculated</u>	<u>Design data</u>	<u>% Difference</u>
1. heat liberated (oil fired)	MBtu	186.45	187.273	0.41
2. heat absorbed by crude	MBtu	148.71	149.4	0.46
by steam		5.11	5.1	0.19
3. thermal efficiency	%	82.5	82.5	0.0
4. heat to stack gas	%	16.0	16.0	0.0
5. heat loss	%	1.55	1.6	3.1

ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย

D.2 Material and Energy Balance Around Exchangers

Table D.1 summarizes heat exchange between each pair of streams. The design data are also illustrated for comparison.

Table D.1 Calculated heat load vs design data for heat exchangers

NO.	EQUIPMENT	FLUID CIRCULATING	FLOW RATE IN-OUT (lb/hr)	TEMP. (°F)		°API	HEAT EXCHANGE (MBtu/hr)	
				IN	OUT		CALCULATED	DESIGNED
1	E-101	S.S. : CRUDE T.S. : LIGHT DISTILLATE	619,150 350,000	80 346	199 176	35.0 50.9	34.98 34.09	35.0
2	E-102	S.S. : CRUDE T.S. : KEROSENE	619,150 94,092	199 383	229 229	35.0 43.9	9.52 8.41	8.8
3	E-103	S.S. : CRUDE T.S. : DIESEL	619,150 98,029	229 510	272 272	35.0 34.3	14.14 14.01	14.4
4	E-104	S.S. : CRUDE T.S. : DIESEL CIR. REFLUX	619,150 134,000	272 540	310 390	35.0 35.3	12.98 12.87	13.4
5	E-105	S.S. : REDUCED CRUDE T.S. : CRUDE	241,040 619,150	697 310	345 452	15.3 35.0	52.18 52.51	56.4
6	E-403	S.S. : LIGHT NAPHTHA T.S. : DIESEL OIL	311,600 116,000	303 540	314 390	76.6 35.3	11.29 11.59	11.6
7	E-106	S.S. : FRACTIONATOR DVHD T.S. : WATER	476,540 5,605,000	252 115	187 99.1		89.10 89.12	89.2
8	E-107	S.S. : FRAC. DVHD PRODUCT T.S. : WATER	84,469 4,580,000	187 95	100 100		22.88 22.90	22.9
9	E-108	S.S. : HEAVY NAPHTHA T.S. : WATER	59,565 250,000	270 95	120 115	53.6	4.87 5.00	5.0
10	E-109	S.S. : KEROSENE T.S. : WATER	94,092 257,500	229 95	120 115	43.9	5.27 5.15	5.15
11	E-110	S.S. : DIESEL T.S. : WATER	98,029 393,000	272 95	120 115	34.3	7.47 7.86	7.86
12	E-111	S.S. : GAS OIL T.S. : WATER	50,245 730,000	611 95	120 115	27.3	14.05 14.60	14.6
13	E-112	S.S. : REDUCED CRUDE T.S. : WATER	241,040 1,130,000	364 95	180 115	15.3	21.55 22.60	22.6

Remark : - S.S. means shell side, and T.S. means tube side.

Appendix E

Physical Properties and Coefficients



Figure E.1 Gravity conversions

Table E.1 Conversion table

Unacceptable unit	Acceptable SI unit with unit conversion factor
ångström	0.1 nm*
atmosphere (standard)	101.325 kPa
Btu†	1.055 056 kJ
Btu/(lb _m ·°F) (heat capacity)	4.186 8 kJ/(kg·K)*
Btu/h	0.293 971 1 W
Btu/ft ²	11.356 53 kJ/m ²
Btu/(ft ² ·h·°F) (heat transfer coefficient)	5.678 263 J/(m ² ·s·K)
Btu/(ft ² ·h) (heat flux)	3.154 591 J/(m ² ·s)
Btu/(ft·h·°F) (thermal conductivity)	1.730 735 J/(m·s·K)
calorie†	4.186 8 J*
cal/(g·°C) (heat capacity)	4.186 8 kJ/(kg·K)*
centipoise (absolute viscosity)	1.0 mPa·s*
centistoke (kinematic viscosity)	1.0 × 10 ⁻⁶ m ² /s*
t (°F)	(t + 459.67)/(1.8) K
t (°R)	t/(1.8) K*
dyne	10.0 μN*
erg	100 pJ*
foot‡	0.3048 m*
ft ³	9.290 304 × 10 ⁻³ m ³ *
ft ³	2.831 685 × 10 ⁻³ m ³
gallon (U.S. liquid)	3.785 412 × 10 ⁻³ m ³
horsepower (550 ft·lbf/s)	745.699 9 W
inch	2.54 × 10 ⁻² m*
in. Hg (60°F) (inches mercury pressure)	3.376 85 kPa
in. H ₂ O (60°F) (inches water pressure)	0.248 84 kPa
kgf (kilogram force)	9.806 65 N*
mile	1 609.344 m*
mm Hg (0°C) (millimeters mercury pressure)	0.133 322 kPa
poise (absolute viscosity)	0.1 Pa·s*
lbf (pounds force)	4.448 222 N
lb _m (pounds mass—avoirdupois)	0.453 592 4 kg
psi (pounds per square inch pressure)	6.894 757 kPa
stoke (kinematic viscosity)	1.0 × 10 ⁻⁴ m ² /s*
yard	0.9144 m*

* Exact equivalence.

† British thermal unit and calorie are reported as the International Table values as adopted in 1956 for all cases in this table. The exact conversion factor for Btu (International Table) to kJ is 1.055 055 852 62. The Btu (thermochemical) is 1.054 350 kJ and the calorie (thermochemical) is exactly 4.184 J. (See footnote § for Table 6).

‡ The foot is reported as the International Table value and holds for all cases of length in this table.




Figure E.2 Properties of petroleum fractions




Figure E.3 Specific heat of liquid hydrocarbon

© 1984 G. A. HOODEN AND K. M. WATSON




Figure E.4 Specific heat of hydrocarbon vapor




Figure E.5 Heat of vaporization of hydrocarbon and petroleum fractions




Figure E.6 Heat capacity per mole of gas
at constant pressure

จุฬาลงกรณ์มหาวิทยาลัย

Appendix F



Cost Estimation Data

F.1 Heat Transfer Area

The required transfer area, A , for a heat exchanger is determined from the expression

$$A = \frac{Q}{U * DTLM}$$

where

Q = net amount of heat transfer

U = overall heat transfer coefficient

$DTLM$ = log mean temperature difference

$$= \frac{(\Delta T_2 - \Delta T_1)}{\ln(\Delta T_2 / \Delta T_1)}$$

Note that, ΔT_1 and ΔT_2 are defined as shown in Figure F.1




Figure F.1 Temperature profiles for a countercurrent heat exchanger

F.2 Overall Heat Transfer Coefficients

The estimates of the overall heat transfer coefficients, U , (including fouling and wall resistances) used in the present study are listed below

Table F.1 Overall heat transfer coefficient


System	U , Btu/(hr* ft^2 * $^{\circ}F$)
Condensing vapor to boiling liquid	250
Condensing vapor to flowing liquid	150
Condensing vapor to gas	20
Liquid to liquid	50
Liquid to gas	20
Gas to gas	10
Partial condenser	30

ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย

F.3 Cost Dataa) Cost Index

Source : Chemical Engineering Journal, McGraw-Hill,
September, 1989.

ECONOMIC INDICATORS

b) Cost of Utilities

- fuel (unit cost as fuel) = 4.30 US\$/MBtu
- cooling water = 0.021 US\$/m³

F.4 Cold Utility Calculation

a) MER design

- Given :
1. cold utility saved by MER design = 36.32 MBtu/hr
 2. Temperature condition of cold stream (cooling water)
 $T_{in} = 95^{\circ}\text{F}$, $T_{out} = 115^{\circ}\text{F}$
 3. Heat capacity (C_p) of cooling water is 1 Btu/lb $^{\circ}\text{F}$
 4. Density (ρ) of cooling water is 1 gm/cm³

The amount of heat absorbed by the cooling water is determined by

$$Q = m C_p \Delta T$$

Thus, the required mass flowrate of cooling water is

$$\begin{aligned} m &= Q / C_p * \Delta T \\ \therefore \text{mass flowrate} &= \frac{36.32 \times 10^6}{1 \times (115-95)} \\ &= 1.816 \times 10^6 \quad \text{lb/hr} \\ \text{or} &= 823.74 \times 10^6 \quad \text{gm/hr} \end{aligned}$$

According to the correlation of Density = mass/volume , and the density water is 1 gm/cm³

$$\begin{aligned} \text{then, volume flowrate} &= 823.74 \times 10^6 \quad \text{cm}^3/\text{hr} \\ \text{or} &= 823.74 \quad \text{m}^3/\text{hr} \end{aligned}$$

b) Relaxed Design

cold utility saved by relaxed design = 23.31 MBtu/hr

$$\begin{aligned} \therefore \text{mass flowrate} &= \frac{23.31 \times 10^6}{1 \times (115-95)} \\ &= 1.16 \times 10^6 \quad \text{lb/hr} \\ \text{or} &= 528.67 \times 10^6 \quad \text{gm/hr} \end{aligned}$$

$$\begin{aligned} \text{then, volume flowrate} &= 528.67 \times 10^6 \quad \text{cm}^3/\text{hr} \\ \text{or} &= 528.67 \quad \text{m}^3/\text{hr} \end{aligned}$$



VITA

Mr. Chaiyot Worravitudomsuk graduated high school from Triam Udom Suksa school in 1982 and received a BS degree in Chemical Engineering from the Department of Chemical Technology, Faculty of Science, Chulalongkorn University in 1986. After then he subsequently studied for a requirement of the Master's Degree in Chemical Engineering at the Department of Chemical Engineering, Faculty of Engineering, Chulalongkorn University from 1986 till 1989.

He also has an experience in working as process engineer at Seagate Technology Co., Ltd. from the early of 1988 till 1989.



ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย