



## เอกสารอ้างอิง

Annual Book of ASTM Standards, Designation: B212-89 and B527-85.

Revision Issued Anually, vol.02.05, June 1993, p.45-46, 245-46.

\_\_\_\_\_. Designation: C373-88. Revision Issued Anually, vol.15.02,  
April 1994, p.114-15.

A.B.D. Van Der Meer and N.P. Slijkerman, Mechanical Strength of  
Magnesium Zinc Ferrites for Yokerings. Proceedings of the  
international conference, Sep.-Oct. 1980, Japan, p.301-305.

B.D.Mosser III, J.S.Reed, and J.R.Varner, The Effect of Granule Size  
on Green Strength Distributions of Dry Pressed Alumina  
Compacts. New York State Collage of Ceramics, Alfred  
University, New York, p. 767-775.

C.P. Chen and R.S.Weisz, Strength of Ferrite Memory Cores. Ceramic  
Bulletin, 51[6] 532-34, 538(1972).

J.S.Reed, Introduction to the Principles of Ceramic Processing.

Joann Waldman, Harvey and Devid W. Johnson, JR. Binder Systems in  
Ferrites. Am. Ceram.soc Bull.59, 637-639(1980).

M.I.Alam, S.A.Jaleel and R.Venugopalan, Effect of Dispersant on  
Grinding Efficiency of a Ferrite Powder. The Am. Ceram. Soc.  
Columbus, p. 109-114(1985).

T. Hiraga, Development of Soft Ferrites in Japan. Ferrites:  
Proceedings of the International Conference, July 1970, Japan,  
p. 179-182.

Treatise on Materials Science and Technology, Dry Pressing. Ceramic  
Fabrication process, volume 9, Edited by Franklin F.Y. Wang,  
p.71-93.


Y. Yamamoto, T. Kuriyama and A. Makino, Magnetic Properties of Mn-Zn  
Ferrites with Fine Grain Sizes for Magnetic Heads. Ferrites:  
Proceedings of the Sixth International Conference on Ferrites  
(ICF 6), Tokyo and Kyoto, Japan 1992.

## สารบัญภาคผนวก


ภาคผนวกที่		หน้า
1	รูปภาพเครื่องมือและอุปกรณ์ .....	98
2	ภาพประกอบแบบพิมพ์อัดขึ้นรูปดิเฟล็คชันโยค(ชุดที่ 1) .....	105
3	ภาพประกอบแบบพิมพ์อัดขึ้นรูปดิเฟล็คชันโยค(ชุดที่ 2) .....	109
4	เอ็กซ์เรย์แพทเทิร์นของ DY-1 ถึง DY-6 .....	117
5	ไฟล์นัมเบอร์ของสารเคมี .....	118
6	มาตรฐานอเมริกันสำหรับวัสดุและการทดสอบ .....	121

ภาคผนวกที่ 1


รูปภาพเครื่องมือและอุปกรณ์




รูปที่ 1.1 Hi-Speed Mill




รูปที่ 1.2 Attrition Mill




รูปที่ 1.3 Electrical Furnace




รูปที่ 1.4 Tube Furnace



รูปที่ 1.5 Hydraulic Press




รูปที่ 1.6 Low-Speed Saw



រូប 1.7 Hall Flowmeter



រូប 1.8 Volumeter




รูปที่ 1.9 Centrifugal Particle Size Analyser




รูปที่ 1.10 X-ray Fluorescence Spectrometer







រូបភាព 1.11 Scanning Electron Microscope



រូបភាព 1.12 Transmission Electron Microscope



រូប 1.13 X-ray Diffractometer





រូប 1.14 Universal Testing Machine

## ภาคผนวกที่ 2



ภาพประกอบแบบพิมพ์อดีตขึ้นรูปดีเฟล็คชั่นโยค (ชุดที่ 1)

2	SOCKET HEAD	13	M6 x 40
4	SOCKET HEAD	12	M8 x 50
8	SOCKET HEAD	11	M8 x 40
1	SPRING	10	φ25x25
2	CLAMP	9	STEEL
1	SUPPORT	8	STEEL
2	GUIDE POST	7	CAST IRON
2	COLUMN	6	φ 25x100
2	GUIDE POST	5	CAST IRON
1	UPPER PUNCH	4	φ100x60
1	LOWER PUNCH	3	φ100x90
1	BASE UPPER	2	25x125x250
1	BASE LOWER	1	25x125x250
no of piece	nomenclature	pos no	dim./mat./misc
list of parts		design problem no	
Scale	works	date: 11 Feb.'92	
1:3	MOLD DEFLECTION YOKE (I)	no	


GATEWAY NATURAL TRACING PAPER 90/95 gm<sup>2</sup> SIZE A4



scale		works		name:	
1:3		Mold D.Y.(I)		date: 11Feb'92	
				no	



		name:	
scale	works	date: 12 FEB, 92	
1:3	MOLD DEFLECTION YOKE(I)		no




scale		works		name:	
1:4		MOLD D.Y.(I)		date: 12 FEB '92	
				no	


ภาคผนวกที่ 3

ภาพประกอบและแยกชิ้นแบบพิมพ์อัดขึ้นรูปดีเฟลคชันโยค(ชุดที่ 2)


1	SUPPORT	11	∅ 65 × 35
2	SUPPORT	10	20 × 50 × 115
1	EJECTOR	9	∅ 40 × 80
1	EJECTOR	8	∅ 41 × 100
1	EJECTOR	7	∅ 53 × 100
1	PIN	6	∅ 10 × 100
1	CYLINDRICAL	5	∅ 125 × 40
1	UPPER BUSH	4	∅ 88 × 60
1	LOWER BUSH	3	∅ 58 × 90
1	UPPER PUNCH	2	∅ 80 × 150
1	LOWOR PUNCH	1	∅ 125 × 150
NO OF PIECE	NOMENCLATURE	POS NO	DIM / MAT / MISC
LIST OF PARTS		DESIGN PROBLEM NO	
SCALE	WORKS	DATE	
1:2	MOLD DEFLECTION YOKE II		NO









No. 1 เหล็กแข็ง (ชุบแข็ง) ผิวเจียรไน จำนวน 1 ชิ้น




No. 2 เหล็กแข็ง (ชุบแข็ง) ฝิวเจียรไน จำนวน 1 ชิ้น




No.3 เหล็กแข็ง (ชุบแข็ง) ผิวเจียรไน จำนวน 1 ชิ้น




No.4 เหล็กแข็ง (ชุบแข็ง) ผิวเจียรไน จำนวน 1 ชิ้น




No.5 เหล็กเหนียวผิวกลึง จำนวน 1 ชิ้น




No.6 เหล็กเหนียวผิวกลึง จำนวน 1 ชิ้น





No. 7 เหล็กเหนียวผิวกลิ้ง จำนวน 1 ชั้น





No. 8 เหล็กเหนียวผิวกลิ้ง จำนวน 1 ชั้น



No. 9 เหล็กเหนียวผิวกลิ้ง จำนวน 1 ชั้น



No.10 เหล็กเหนียวผิวละเอียด จำนวน 2 ชิ้น




มาตราส่วน 1:2

No.11 เหล็กเหนียว จำนวน 1 ชิ้น

ภาคผนวก 4

เอ็กซ์เรย์ผงเทิร์นของ DY-1 ถึง DY-6



ภาคผนวกที่ 5

ไฟล์นามเบอร์ (File No.) ของสารเคมี

17-464

d	2.53	2.96	1.48	4.84	MgFe <sub>2</sub> O <sub>4</sub> (low temperature)				
I/I <sub>1</sub>	100	40	35	4		Magnesium Iron Oxide (Magnesioferrite, low)			
Rad. CuK <sub>α</sub>	λ 1.542	Filter Ni	Dia.	d Å	I/I <sub>1</sub>	hkl	d Å	I/I <sub>1</sub>	hkl
Cut off	1/1	Diffractometer		4.84	4	111	0.821	4	862
Ref.	W.C. Allen, School of Ceramics, Rutgers Univ., New Brunswick, N.J. (1965)			2.96	40	220	.810	8	951,773
Sys.	Cubic	S.G.	Fd3m (227)	2.525	100	311			
a <sub>0</sub>	8.375	b <sub>0</sub>	c <sub>0</sub>	2.418	2	222			
α	β	γ	Z 8	2.094	25	400			
Ref. Ibid.			Dx 4.522	1.709	14	422			
εa	nωβ 2.35 (calc)	εγ	Sign	1.612	30	511,333			
2V	D	mp	Color Red to brown	1.481	35	440			
Ref. Ibid.				1.324	6	620			
				1.277	8	533			
				1.208	2	444			
				1.119	4	642			
				1.090	12	731,553			
				1.047	6	800			
				0.987	4	822,660			
				.967	8	751,555			
				.936	2	840			
				.893	<1	664			
				.878	6	931			
				.855	10	844			

22-1012

d	2.54	2.98	1.49	4.87	ZnFe <sub>2</sub> O <sub>4</sub>				
I/I <sub>1</sub>	100	35	35	7		Zinc Iron Oxide (Franklinite)			
Rad. CuK <sub>α</sub>	λ 1.54056	Filter Mono.	Dia.	d Å	I/I <sub>1</sub>	hkl	d Å	I/I <sub>1</sub>	hkl
Cut off	1/1	Diffractometer	1/1 cor. = 3.8	4.87	7	111	.9684	2	662
Ref.	National Bureau of Standards, Mono. 25, Sec. 9 (1971)			2.984	35	220	.9439	2	840
Sys.	Cubic	S.G.	Fd3m (227)	2.543	100	311	.8999	1	664
a <sub>0</sub>	8.4411	b <sub>0</sub>	c <sub>0</sub>	2.436	6	222	.8848	5	931
α	β	γ	Z 8	2.109	17	400	.8616	8	844
Ref. Ibid.			Dx 5.324	1.937	1	331	.8277	4	1020
				1.723	12	422	.8159	6	951
				1.624	30	511	.8122	2	1022
				1.491	35	440			
				1.4270	1	531			
				1.3348	4	620			
				1.2872	9	533			
				1.2721	4	622			
				1.2184	2	444			
				1.1820	1	711			
				1.1280	5	642			
				1.0990	11	731			
				1.0553	4	800			
				0.9949	2	822			
				.9747	6	751			



7-239 MINOR CORRECTION

d	2.37	1.77	1.79	1.77	Mg(OH) <sub>2</sub>	★				
I/I <sub>1</sub>	100	90	55	90						
					MAGNESIUM HYDROXIDE	(BRUCITE)				
Rad. CuKα <sub>1</sub>	λ 1.5405	Filter Ni	Dia.		d Å	I/I <sub>1</sub>	hkl	d Å	I/I <sub>1</sub>	hkl
Cutoff	I/I <sub>1</sub> DIFFRACTOMETER				4.77	∞C	001	0.3001	<1	105
Ref.	NBS CIRCULAR 53, VOLUME 6 (1956)				2.725	6	100	.8974	2	204
					2.365	100	101	.8923	2	301
					1.794	55	102	.8643	6	213
Sys. Hexagonal (TRIGONAL)	S.G. R3c - P6m1 (164)				1.573	35	110	.8156	4	115
a	3.147	b	c 4.769	A	1.494	16	111	.7865	4	220
β		γ	Z	Dx 2.37	1.373	16	103			
Ref. Ibid.					1.363	2	200			
					1.310	12	201			
					1.192	2	004			
f 1.561	n 1.581	γ	Sign +		1.183	10	202			
μV	D 2.39	mp	Color COLORLESS		1.118	2	113			
Ref. Ibid.	DANA'S SYSTEM OF MINERALOGY 7TH ED. VOL 1				1.092	4	104			
					1.034	6	203			
					1.030	2	110			
SAMPLE PREPARED AT NBS FROM MgO AND WATER HELD AT 60°C AND 20,000 PSI FOR 3 DAYS; SPECT. ANALYSIS SHOWS < 0.1% Ca; < 0.01% S, AL, B, Fe, Si, SA, T; < 0.001% O, P, CR, CU. CO <sub>2</sub> STRUCTURE TYPE. PATTERN MADE AT 26°C.					1.0067	3	211			
					0.9543	2	005			
					.9503	6	114			
					.9455	3	212			
					.9085	4	100			

CALCULATED PATTERN - PEAK HEIGHT

24-72 See 24-72A 24-72A

d Å	2.70	2.52	1.70	100	70	36	d Å				d Å			
I/I <sub>0</sub>							I/I <sub>0</sub>				I/I <sub>0</sub>			
hkl							hkl				hkl			
Fe <sub>2</sub> O <sub>3</sub>							1.4543	21	300					
Iron Oxide Hematite							1.3514	2	208					
							1.3133	7	1010					
							1.3078	4	119					
							1.2595	4	220					
Ref. Smith et al., Annual Report to the Joint Committee on Powder Diffraction Standards (1973)							1.2285	2	306,036					
							1.1908	3	128,312					
							1.1645	3	0210					
Sys. Hexagonal	S.G. R3c (167)	Dx 5.255	Z 6				1.1416	4	133					
a	5.038	b	c 13.772				1.1042	4	226					
Ref. Blake et al., Am. Min., 51:125 (1966)							1.0571	3	2110					
							0.9611	3	104					
							.9596	3	0114					
							.9521	2	110					
Scale factor (Integrated Intensities)							.9090	2	1310					
k	1.54050						.8794	2	115,146					
							.8448	2	121,254					
d Å	I/I <sub>0</sub>	hkl	d Å	I/I <sub>0</sub>	hkl	d Å	I/I <sub>0</sub>	hkl	d Å	I/I <sub>0</sub>	hkl	d Å	I/I <sub>0</sub>	hkl
3.686	33	012	2.080	2	202									
2.703	100	104	1.6428	31	024									
2.519	70	110	1.6066	36	116									
2.295	2	006	1.6013	8	018,122									
2.208	17	113	1.4873	22	214									

FORM CP

16-154

d	2.49	2.77	1.54	4.94	Mn <sub>2</sub> O <sub>4</sub>	MnO.Mn <sub>2</sub> O <sub>3</sub>				
I/I <sub>1</sub>	100	90	80	30	Manganese Oxide	Hausmannite				
Rad. FeKα	λ 1.9373	Filter Mn	Dia. 57.3mm		d Å	I/I <sub>1</sub>	hkl	d Å	I/I <sub>1</sub>	hkl
Cutoff	I/I <sub>1</sub> Visual				4.94	30	011	1.280	40	143
Ref. E.W. Nuffield, in Berry & Thompson, Geol. Soc. Amer. Mem. 35:195 (1962)					3.09	50	112	1.246	10	242
					2.89	30	020	1.233	20	044
					2.77	90	013	1.194	30	127,136
Sys. Tetragonal	S.G. I4 <sub>1</sub> /amd (141)				2.49	100	121	1.180	30	008
a	5.76	b	c 2.44	A	2.36	40	004	1.133	10	244
β		γ	Z 4	Dx 4.84	2.04	40	220	1.125	40	145
Ref. Aminoff, Z. Krist. 64:475 (1926) - Langban.					1.825	20	024	1.101	20	152
					1.795	50	015	1.083	40	053,343
					1.706	30	132	1.064	20	251,046
f 2.15 (Li)	n 2.46 (Li)	γ	Sign -		1.642	20	033	1.030	40	237,336
μV	D 4.84	mp	Color Brownish black		1.570	50	231	1.019	50	154
Ref. Dana's System of Mineralogy, 7th Edition					1.544	80	224			
					1.468	10	116			
					1.445	40	134,040			
					1.423	5	233			
					1.382	5	141,026			
					1.350	30	035			
					1.306	10	332			
					1.292	10	240			
Sample from Ilmenau, Thuringia, Germany. Same pattern given by mineral from Langban, Sweden and Ilfeld, Harz, (Randoehr, Symp. on Manganese Tom 1, Int. Geol. Congress Mexico, 1956)										

5-0664 MAJOR CORRECTION

d	2.48	2.82	2.60	2.816	ZnO
I/I <sub>1</sub>	100	71	56	71	ZINC OXIDE (ZINCITE)
Rad. CuKα <sub>1</sub>	λ 1.5405	Filter Ni			
Dia.	Cut off	Coll.			
I/I <sub>1</sub>	G. C. DIFFRACTOMETER	d corr. abs.?			
Ref.	SWANSON AND FUYAT, NES CIRCULAR 539, Vol. 2 (1953)				
Sys.	HEXAGONAL	S.G. C <sub>6v</sub> - P6 <sub>3</sub> mc			
a	3.249	b	5.205	A	C 1.60
β		γ	Z 2		
Ref.	IBID.				
εα		nωβ	εγ	Sign	
ZV	D <sub>x</sub> 5.680 mp	Color			
Ref.	IBID.				
SAMPLE FROM NEW JERSEY ZINC CO. SPECT. ANALYSIS SHOWS < 0.001% EACH OF Mg, Si AND CA. X-RAY PATTERN AT 26°C.					
TO REPLACE 1-1136, 3-0752, 3-0888, 3-0891.					

4-0777 MAJOR CORRECTION

d	2.41	1.70	2.78	2.778	CaO
I/I <sub>1</sub>	100	45	34	34	CALCIUM OXIDE (LIME)
Rad. CuKα <sub>1</sub>	λ 1.5405	Filter Ni			
Dia.	Cut off 50	Coll.			
I/I <sub>1</sub>	G. C. DIFFRACTOMETER	d corr. abs.?			
Ref.	BRANSON AND TATGE, UC FEL. REPORTS, NES (1950)				
Sys.	CUBIC	S.G. O <sub>h</sub> - Fm3m			
a	4.3105	b	A	C	
β		γ	Z 4		
Ref.	IBID.				
εα		nωβ 1.937	εγ	Sign	
ZV	D <sub>x</sub> 3.345 mp (NBS)	Color			
Ref.	(NBS)				
NBS ANALYSIS SHOWS ABOUT 0.21% MgO, 0.19% Ba, AND NO OTHER IMPURITY OVER 0.04% AT 27°C					
TO REPLACE 1-1160, 2-1089, 3-1123					

5-0490 MINOR CORRECTION

d	3.34	4.26	1.82	4.26	SiO <sub>2</sub>
I/I <sub>1</sub>	100	35	17	35	SILICON OXIDE QUARTZ, LCR
Rad. CuKα <sub>1</sub>	λ 1.5405	Filter Ni			
Dia.	Cut off	Coll.			
I/I <sub>1</sub>	G. C. DIFFRACTOMETER	d corr. abs.?			
Ref.	SWANSON AND FUYAT, NES CIRCULAR 539, Vol. III (1953)				
Sys.	HEXAGONAL	S.G. D <sub>3d</sub> - P3 <sub>2</sub> 1			
a	4.913	b	5.405	A	C 1.10
β		γ	Z 3		
Ref.	IBID.				
εα		nωβ 1.544	εγ 1.553	Sign +	
ZV	D <sub>x</sub> 2.647 mp	Color			
Ref.	IBID.				
SAMPLE FROM LAKE TOXAWAY, N.C. SPECT. ANAL. < 0.05% AL; < 0.001% CA, CU, FE, MG. X-RAY PATTERN AT 25°C.					
REPLACES 1-0649, 2-0458, 2-0459, 3-0427, 3-0444, 2-0471, 3-0419.					

ภาคผนวกที่ 6

มาตรฐานอเมริกันสำหรับวัสดุและการทดสอบ



Designation: B 212 - 89

## Standard Test Method for Apparent Density of Free-Flowing Metal Powders<sup>1</sup>

This standard is issued under the fixed designation B 212; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

### 1. Scope

1.1 This test method describes a procedure for determining the apparent density of free-flowing metal powders and is suitable for only those powders that will flow unaided through the specified Hall flowmeter funnel.

1.2 *This standard may involve hazardous materials, operations, and equipment. This standard does not purport to address all of the safety problems associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

### 2. Referenced Documents

- 2.1 *ASTM Standards:*  
 B 213 Test Method for Flow Rate of Metal Powders<sup>2</sup>  
 B 215 Practices for Sampling Finished Lots of Metal Powders<sup>2</sup>  
 B 243 Terminology of Powder Metallurgy<sup>2</sup>

### 3. Summary of Test Method

3.1 A volume of powder is permitted to flow into a container of definite volume under controlled conditions. The weight of powder per unit volume is determined and reported as apparent density.

### 4. Significance and Use

4.1 This test method provides a guide for evaluation of the apparent density physical characteristic of powders. The density measured bears some relationship to the weight of powder that will fill a fixed volume press cavity when parts are being made. The degree of correlation between the results of this test and the quality of powders in use will vary with each particular application.

### 5. Apparatus

5.1 *Powder Flowmeter Funnel*<sup>3</sup>—A standard Hall flowmeter funnel (Fig. 1) having a calibrated orifice.

5.2 *Density Cup*<sup>3</sup>—A cylindrical cup (Fig. 1) having a capacity of  $25 \pm 0.05$  cm<sup>3</sup>.

5.3 *Stand*<sup>3</sup>—A stand (Fig. 1) to support the powder flowmeter concentric with the density cup so that the bottom

of the powder flowmeter orifice is 1 in. (25 mm) above the top of the density cup when the apparatus is assembled as shown in Fig. 1.

5.4 *Base*—A level, vibration-free base to support the powder flowmeter.

5.5 *Balance*, having a capacity of at least 200 g and a sensitivity of 0.1 g.

### 6. Test Specimen

6.1 The test specimen shall consist of a volume of approximately 30 to 40 cm<sup>3</sup> of metal powder.

6.2 The test specimen shall be tested as sampled. Note, however, that moisture, oils, stearic acid, stearates, waxes, etc., may alter the characteristics of the powder.

### 7. Procedure

7.1 Carefully load the test specimen into the flowmeter funnel and permit it to run into the density cup through the discharge orifice. Take care not to move the density cup.

7.2 When the powder completely fills and overflows the periphery of the density cup, rotate the funnel approximately 90° in a horizontal plane so that the remaining powder falls away from the cup.

7.3 Using a nonmagnetic spatula with the blade held perpendicular to the top of the cup, level off the powder flush with the top of the density cup. Take care to avoid jarring the apparatus at any time.

7.4 After the leveling operation, tap the density cup lightly on the side to settle the powder to avoid spilling in transfer.

7.5 Transfer the powder to the balance and weigh to the nearest 0.1 g.

### 8. Calculation

8.1 Calculate the apparent density as follows:

$$\text{Apparent density, g/cm}^3 = \text{weight in grams} \times 0.04$$

### 9. Report

9.1 Results shall be reported as apparent density to the nearest 0.01 g/cm<sup>3</sup>.

### 10. Precision and Bias

10.1 The following criteria should be used to judge acceptability of the results at the 95 % confidence level.

10.1.1 *Repeatability*—Duplicate results by the same operator should be considered suspect if they differ by more than 0.9 %.

10.1.2 *Reproducibility*—The results submitted by each of two laboratories should not be considered suspect unless they differ by more than 6.0 %.


<sup>1</sup> This test method is under the jurisdiction of ASTM Committee B-9 on Metal Powder and Metal Powder Products and is the direct responsibility of Subcommittee B09.02 on Base Metal Powders.

Current edition approved Jan. 27, 1989. Published March 1989. Originally published as B 212 - 46 T. Last previous edition B 212 - 82.

<sup>2</sup> *Annual Book of ASTM Standards*, Vol 02.05.

<sup>3</sup> The flowmeter funnel, density cup, and stand are available from Alcan Powder and Pigments, Division of Alcan Aluminum Corp., 901 Lehigh Ave., Union, NJ 07083-7632.

## ASTM B 212



## Metric Equivalents

in.	mm
1/10	2.5
1/8	3.2
1	25

FIG. 1 Flowmeter Apparatus

The American Society for Testing and Materials takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, 1916 Race St., Philadelphia, PA 19103.



Designation: B 527 – 85 (Reapproved 1991)<sup>1</sup>

## Standard Test Method for Tap Density of Powders of Refractory Metals and Compounds by Tap-Pak Volumeter<sup>1</sup>

This standard is issued under the fixed designation B 527; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

<sup>1</sup> NOTE—The Keywords section was added editorially, and other editorial changes made, in August 1991.

### 1. Scope

1.1 This test method covers determination of the tap density (packed density) of refractory metal powders and compounds by means of the Tap-Pak Volumeter.<sup>2</sup>

1.2 *This standard does not purport to address the safety problems, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

### 2. Significance and Use

2.1 This test method covers the evaluation of the tapped density physical characteristic of powders. The degree of correlation between the results of this test and the quality of powders in use will vary with each particular application and has not been fully determined.

### 3. Apparatus

3.1 *Graduated Cylinder*,<sup>3</sup> calibrated to contain 25 mL at 20°C, internal diameter 15 mm, height 180 mm and weight approximately 60 g.

3.2 *Holder*—A cylinder holder weighing 1 lb (454 g).

3.3 *Tapping Device*, consisting of a baseplate with single-phase a-c condenser motor, with worm drive, reduction ratio 15 to 1, cam shaft speed 250 r/min, tapping stroke travel 3.2 mm.

3.4 *Counter*—A four-digit adjustable counter, which can be preset to deliver numbers of taps between 1 and 9999.

3.5 *Balance*, having a capacity of at least 100 g and a sensitivity of 0.1 g.

### 4. Test Specimen

4.1 The test specimen shall be 50 g except as noted in 4.2.

4.2 For refractory metal and compound powders too voluminous to fit into the 25-mL graduated cylinder, reduce sample size to 20 g or 10 g, as necessary, and follow the standard procedure.

### 5. Procedure

5.1 Weigh 50 g of the test specimen to an accuracy of  $\pm 0.1$  g.

5.2 Pour the test specimen carefully into the graduated cylinder, using a funnel. To ensure proper level, rotate the funnel while pouring the test specimen.

5.3 Preset the counter for 3000 taps.

5.4 Start tapping device.

5.5 Read the tapped volume,  $V$ , in millilitres, by calculating the mean value between the highest and the lowest point at the tapped volume.

### 6. Calculation and Report

6.1 Calculate tap density in grams per cubic centimetre, to the nearest tenth by dividing 50 g (10 or 20 g for samples as noted in 4.2) by the tapped volume,  $V$ , read in millilitres, as follows:

$$\text{Tap density, g/cm}^3 = 50 \text{ g}/V$$

### 7. Precision and Bias

7.1 Precision has been determined from round-robin testing performed prior to the approval of this test method. Those results which have been re-verified show a precision of from  $\pm 1$  to 2 % of the value determined as the  $2\sigma$  limits. The variation depends upon the tap density of the powder being determined which can vary between 2.0 and 8.0 g/cm<sup>3</sup>.

7.2 Bias cannot be stated since there is no universally accepted standard instrument, nor are instruments sold as certified standards.

### 8. Keywords

8.1 molybdenum; packed density; powder(s); refractory metals; rhenium; tantalum; tap density; Tap-Pak Volumeter; tungsten; tungsten carbide

<sup>1</sup> This test method is under the jurisdiction of ASTM Committee B-9 on Metal Powders and Metal Powder Products and is the direct responsibility of Subcommittee B09.03 on Refractory Metal Powders.

Current edition approved Aug. 30, 1985. Published December 1985. Originally published as B 527 – 70. Last previous edition B 527 – 81.

<sup>2</sup> Tap-Pak Volumeter Model No. JEL ST2 manufactured by J. Engelsmann A.G. of Ludwigshafen a. Rh. West Germany. Available through Shandon Southern Instruments Inc., 171 Industry Drive, Pittsburgh, PA 15275.

<sup>3</sup> Corning, No. 3046, Pyrex Brand, has been found satisfactory for this purpose.

 B 527

*The American Society for Testing and Materials takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, 1916 Race St., Philadelphia, PA 19103.*



Designation: C 373 - 88

## Standard Test Method for Water Absorption, Bulk Density, Apparent Porosity, and Apparent Specific Gravity of Fired Whiteware Products<sup>1</sup>

This standard is issued under the fixed designation C 373; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

### 1. Scope

1.1 This test method covers procedures for determining water absorption, bulk density, apparent porosity, and apparent specific gravity of fired unglazed whiteware products.

1.2 *This standard may involve hazardous materials, operations, and equipment. This standard does not purport to address all of the safety problems associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

### 2. Significance and Use

2.1 Measurement of density, porosity, and specific gravity is a tool for determining the degree of maturation of a ceramic body, or for determining structural properties that may be required for a given application.

### 3. Apparatus and Materials

3.1 *Balance*, of adequate capacity, suitable to weigh accurately to 0.01 g.

3.2 *Oven*, capable of maintaining a temperature of  $150 \pm 5^\circ\text{C}$  ( $302 \pm 9^\circ\text{F}$ ).

3.3 *Wire Loop, Halter, or Basket*, capable of supporting specimens under water for making suspended mass measurements.

3.4 *Container*—A glass beaker or similar container of such size and shape that the sample, when suspended from the balance by the wire loop, specified in 3.3, is completely immersed in water with the sample and the wire loop being completely free of contact with any part of the container.

3.5 *Pan*, in which the specimens may be boiled.

3.6 *Distilled Water*.

### 4. Test Specimens

4.1 At least five representative test specimens shall be selected. The specimens shall be unglazed and shall have as much of the surface freshly fractured as is practical. Sharp edges or corners shall be removed. The specimens shall contain no cracks. The individual test specimens shall weigh at least 50 g.

### 5. Procedure

5.1 Dry the test specimens to constant mass (Note) by

heating in an oven at  $150^\circ\text{C}$  ( $302^\circ\text{F}$ ), followed by cooling in a desiccator. Determine the dry mass,  $D$ , to the nearest 0.01 g.

NOTE—The drying of the specimens to constant mass and the determination of their masses may be done either before or after the specimens have been impregnated with water. Usually the dry mass is determined before impregnation. However, if the specimens are friable or evidence indicates that particles have broken loose during the impregnation, the specimens shall be dried and weighed after the suspended mass and the saturated mass have been determined, in accordance with 5.3 and 5.4. In this case, the second dry mass shall be used in all appropriate calculations.

5.2 Place the specimens in a pan of distilled water and boil for 5 h, taking care that the specimens are covered with water at all times. Use setter pins or some similar device to separate the specimens from the bottom and sides of the pan and from each other. After the 5-h boil, allow the specimens to soak for an additional 24 h.

5.3 After impregnation of the test specimens, determine to the nearest 0.01 g the mass,  $S$ , of each specimen while suspended in water. Perform the weighing by placing the specimen in a wire loop, halter, or basket that is suspended from one arm of the balance. Before actually weighing, counterbalance the scale with the loop, halter, or basket in place and immerse in water to the same depth as is used when the specimens are in place. If it is desired to determine only the percentage of water absorption, omit the suspended mass operation.

5.4 After the determination of the suspended mass or after impregnation, if the suspended mass is not determined, blot each specimen lightly with a moistened, lint-free linen or cotton cloth to remove all excess water from the surface, and determine the saturated mass,  $M$ , to the nearest 0.01 g. Perform the blotting operation by rolling the specimen lightly on the wet cloth, which shall previously have been saturated with water and then pressed only enough to remove such water as will drip from the cloth. Excessive blotting will introduce error by withdrawing water from the pores of the specimen. Make the weighing immediately after blotting, the whole operation being completed as quickly as possible to minimize errors due to evaporation of water from the specimen.

### 6. Calculation

6.1 In the following calculations, the assumption is made that  $1\text{ cm}^3$  of water weighs 1 g. This is true within about 3 parts in 1000 for water at room temperature.

6.1.1 Calculate the exterior volume,  $V$ , in cubic centimetres, as follows:

$$V = M - S$$

<sup>1</sup> This test method is under the jurisdiction of ASTM Committee C-21 on Ceramic Whitewares and Related Products and is the direct responsibility of Subcommittee C21.03 on Fundamental Properties.

Current edition approved Sept. 30, 1988. Published November 1988. Originally published as C 373 - 55 T. Last previous edition C 373 - 72 (1982).



 C 373

6.1.2 Calculate the volumes of open pores  $V_{OP}$  and impervious portions  $V_{IP}$  in cubic centimetres as follows:

$$V_{OP} = M - D$$

$$V_{IP} = D - S$$

6.1.3 The apparent porosity,  $P$ , expresses, as a percent, the relationship of the volume of the open pores of the specimen to its exterior volume. Calculate the apparent porosity as follows:

$$P = [(M - D)/V] \times 100$$

6.1.4 The water absorption,  $A$ , expresses as a percent, the relationship of the mass of water absorbed to the mass of the dry specimen. Calculate the water absorption as follows:

$$A = [(M - D)/D] \times 100$$

6.1.5 Calculate the apparent specific gravity,  $T$ , of that portion of the test specimen that is impervious to water, as follows:

$$T = D/(D - S)$$

6.1.6 The bulk density,  $B$ , in grams per cubic centimetre, of a specimen is the quotient of its dry mass divided by the exterior volume, including pores. Calculate the bulk density as follows:

$$B = D/V$$

## 7. Report

7.1 For each property, report the average of the values obtained with at least five specimens, and also the individual values. Where there are pronounced differences among the individual values, test another lot of five specimens and, in addition to individual values, report the average of all ten determinations.

## 8. Precision and Bias

8.1 This test method is accurate to  $\pm 0.2\%$  water absorption in interlaboratory testing when the average value recorded by all laboratories is assumed to be the true water absorption. The precision is approximately  $\pm 0.1\%$  water absorption on measurements made by a single experienced operator.

*The American Society for Testing and Materials takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, 1916 Race St., Philadelphia, PA 19103.*



### ประวัติผู้เขียน

นายสฤทธิสาร อนันตรัตนชัย เกิดวันที่ 4 ตุลาคม พ.ศ. 2504 ที่เขตบางกอกน้อย กรุงเทพมหานคร สำเร็จการศึกษาปริญญาตรีครุศาสตร์บัณฑิต สาขาอุตสาหกรรม-เครื่องมือกล ภาควิชาครุศาสตร์อุตสาหกรรม คณะวิศวกรรมเทคโนโลยี สถาบันเทคโนโลยีราชมงคล ในปีการศึกษา 2528 ต่อมาสำเร็จการศึกษาปริญญาตรีวิศวกรรมศาสตร์บัณฑิต สาขาวิศวกรรมอุตสาหกรรม ภาควิชาวิศวกรรมเทคโนโลยี สถาบันเทคโนโลยีราชมงคล ในปีการศึกษา 2533 และเข้าศึกษาต่อในหลักสูตรวิทยาศาสตรมหาบัณฑิต ที่จุฬาลงกรณ์มหาวิทยาลัย เมื่อ พ.ศ. 2533 ภาคนโยบาย ปัจจุบันรับราชการที่ สถาบันเทคโนโลยีราชมงคล วิทยาเขตนนทบุรี อำเภอเมือง จังหวัดนนทบุรี