

REFERENCES

ภาษาไทย

ฝ่ายเศรษฐกิจการปศุสัตว์ กองแผนงาน กรมปศุสัตว์. ข้อมูลทางเศรษฐกิจการปศุสัตว์ ประจำปี 2532, (2533) : 16-45.

สม ยังเมือง . การบำบัดน้ำเสียจากโรงเรือนสัตว์. กองสุขาภิบาล กรมอนามัย กระทรวงสาธารณสุข กรุงเทพมหานคร. (2533) : 1-66.

วิพิชญ์ ใจบริรักษ์สังเคราะห์ . การตรวจเนื้อ กองความคุ้มครองราษฎร์ กรมปศุสัตว์ กรุงเทพมหานคร, (2519) : 1-23, 66-92.

ภาษาอังกฤษ

AZAD, H.S. Industrial wastewater management handbook. New York : Mc Graw-hill book company, (1976) : 177-543.

BULL, M.A., STERRITT, R.M. and LESTER, J.N. The influence of COD hydraulic, temperature and pH shocks on the stability of an untreated fluidised bed reactor. J. Chem. Tech. Biotechnol V33B N4 (December 1983) : 221-230.

CORDOBA, P.R. RIERA, F.S. and SIVERIZ, F. Temperature effects on upflow anaerobic filter performance. Environmental Technology Letters V9 N8 (August 1988) : 769-774.

DE LACLOS, H.F. and PAVIA, A. The valorization of slaughterhouse by-products : methane fermentation of stercoraceous solids either alone or mixed with urban wastes. Biomass for Energy and Industry (Proc. 1987) : 891-897.

GRADY, C.P.L. and L/m, C.L. Biological wastewater treatment. New York : Marcel Dekker Inc. (1980) : 937-948.

GUTTERIDGE, Meatworks effluent treatment first "Australian meat technology group of the AIFST" seminar (1978). Brisbane, Australia.

HICKEY, R.F., WU, W.-M., VEIGA, M.C. and JONES, R. Start-up, operation, monitoring and control of high-rate anaerobic treatment suystems. Water Science and Technology, V24 N8 (1991) : 207-255.

IZA, J., COLLERAN, E., PARIS, J.M. and WU, W.-M. International workshop on anaerobic treatment technology for municipal and industrial wastewaters : summary paper. Water Science and Technology V24 N8 (1991) : 1-16.

IZA, J., PALENCIA, J.I., FDZ-POLANCO, F. Wastewater management in a sugar beet factory : A case study of comparison between anaerobic technologies. Water Science and Technology V18 N12 (1986) : 73-86.

KOIRALA, R. Effects of operating parameters on anaerobic (upflow) filter performance, AIT Master's Thesis, Asian Institute of Technology, Bangkok, (1987)

LETTINGA, G. and Pol, L.W.H. Advanced reactor design, operation and economy. Water Science and Technology V18 N12 (1986) : 99-108.

LETTINGA, G. and Pol, L.W.H. UASB-process design for various types of wastewaters. Water Science and Technology V24 N8 (1991) : 87-107.

LETTINGA, G., ZEHNDER, J.T.C., GROTHUIS EN, L.W., POL, H. Granular anaerobic sludge ; microbiology and technology. Proc. of the GASMAT- workshop, Netherlands, (25-27 October 1987) : 22-31.

LUND, H.F. Industrial pollution control handbook. New York : Mc Graw-hill book company, (1971)

MCCARTY, P.L. Anaerobic waste treatment fundamentals, environmental requirements and control. Public Works (1964) : 123-126.

MCCARTY, P.L. and MOSEY, F.E. Modelling of anaerobic digestion processes (A discussion of concepts) Water Science and Technology V24 N8 (1991) : 17-33

MCINERNEY, M.J. and BRYANT, M.P. Metabolic stages and energetics of microbial anaerobic digestion. Proc. of the first international symposium on anaerobic digestion., University college, Cardiff,Wales, (September 1979) : 91-98.

METCALF and EDDY, Inc. Wastewater Engineering, McGraw-Hill Book Co., Ltd., New Your (1985).

OANH, N.T.K. Assessment and control of wastewater in meat factories and slaughterhouses, AIT Master's Thesis, Asian Institute of Technology, Bangkok, 1991.

PFEFFER, J.T. Anaerobic digestion processes. Proc. of the first international symposium on anaerobic digestion., University college, Cardiff,Wales, (September 1979) : 15-35.

SAYED, S., DE ZEEUW, W., and LETTINGA, G. Anaerobic treatment of slaughterhouse waste using a flocculent sludge UASB reactor. Agricultural Wastes V11 N3 (1984) : 197-226.

SAYED, S., DE ZEEUW, W. Performance of a continuously operated flocculent sludge UASB reactor with slaughterhouse wastewater. Biological Wastes V24 N3 (1988) : 199-212.

SAYED, S., VAN CAMPEN, S. and LETTINGA, G. Anaerobic treatment of slaughterhouse waste using a granular sludge UASB reactor. Biological Wastes V21 N1 (1987) : 11-28.

SEYFRIEND, C.F., Overview of the anaerobic waste treatment process with examples from operating plants, Institut fuer Siedlungswasserwirtschaft und Abfalltechnik Hannover, University of Hannover/FRG.

SOUZA, M.E. Criteria for the utilization, design and operation of UASB reactors WAter Science and Technology V18 N21 (1986) : 55-69.

STANDARD METHODS. Standard methods for the examination of water and wastewater. 16th Ed., APHA, AWWA, and the WPCF, New York (1990).

STEINER, A., WILDENAUER, F.X. and KANDLER, O. Anaerobic digestion and methane production of slaughterhouse wastes. Energy from Biomass, International Proc. : 474-478.

TOLDRA, F., FLORS, A., LEQUERICA, J.L. and VALLES, Fluidized bed anaerobic biodegradation of food industry wastewater. Biological Waste V21 N4 (1987) : 55-61.

UTTAPAB, D. Application of membrane process in the utilization of abattoir effluents, KMIT Master's Thesis, King Mongkut Institute of Technology, Bangkok, 1985

VAN VELSEN, A.F.M. and LETTINGA, G. Effect of feed composition on digester performance. Proc. of the first international symposium on anaerobic digestion., University college, Cardiff, Wales, (September 1979) : 113-131.

VERINK, J., JOSHI, D.L. The need for pilot-scale research on anaerobic wastewater treatment. Asian Institute of Technology, BKK, Thailand

VIEIRA, S.M.M. and SOUZA, M.E. Development of technology for the use of the UASB reactor in domestic sewage treatment. Water Science and Technology V18 N12 (1986) : 109-121.

WEILAND, P. and ROZZI, A. The start-up, operation and monitoring of high-rate anaerobic treatment systems : discusser's report. Water Science and Technology V24 N8 (1991) : 257-277.

YOUNG, J.C. and Mc CARTY, P.L. The anaerobic filter for waste treatment. JWPCF, V41 N5 P2 (1969) : R160-R173.

YOUNG, J.C. Factors affecting the design and performance of upflow anaerobic filters. Water Scince and Technology V24 N8 (1991) : 133-155.

YOUNG, J.C. and DAHAB, M.F. Operational characteristics of anaerobic packed-bed reactors. Biotechnology and Bioengineering N12 (1982) : 303-316.

Appendix A

Production activity

The factory working week is Monday to Saturday, Sunday is a holiday and no killing takes place on Buddha days. From 8.00 am. to 5.00 pm. all procedures are in operation following the schedule below.

Time	Operation
8:00 - 8:20 a.m.	Start hog/cattle killing, meat processing
8:30 - 8:50	Start hog offal processing
9:00 - 9:30	Start cattle offal processing
10:00 - 10:15	Tea break
12:00	Finish cattle killing and hog killing if number of hogs about 300
12:00 - 1:00 p.m.	Lunch Break
1:00 - 2:00	Finish hog killing if number of hogs about 400-500
2:30 - 3:00	Finish hog offal processing
3:00 - 3:15	Tea Break
3:15 - 4:00	Washing in hog line
4:00 - 4:30	Finish cattle offal processing
4:00 - 5:00	Washing in cattle line

At night, slaughtering begins at 7.00 p.m. and all procedures continue until finish around 9.00 p.m.

After killing, 5-10% of meat productivity was used for processing. Hogs were regularly killed, approximately 300 in the day time and 50 at night but only around 40 cattle were killed weekly so 1500-3000 kg. pork was daily processed while 500-700 kg. beef was weekly processed.

Appendix B

COD Raw Data

COD of Anaerobic Fixed-Bed Reactor

DATE	DAY-NR	INF.COD Total	EFF.COD Filter	%EFF.(T)	%EFF.(F)
<hr/>					
16-AUG.	1	466	193	258	109
17-AUG.	2	339	162	121	67
19-AUG.	4	225	181	54	38
22-AUG.	7	806	264	178	27
24-AUG.	9	566	397	166	64
26-AUG.	11	194	121	87	74
29-AUG.	14	768	288	176	120
31-AUG.	16	237	126	87	59
02-SEP.	18	894	466	345	105
05-SEP.	21	185	54	61	28
07-SEP.	23	225	122	92	23
09-SEP.	25	240	118	88	34
12-SEP.	28	142	32	68	20
Avg.		407	194	137	59
<hr/>					
FLOWRATE = 0.3 m ³ /h					
14-SEP.	30	177	73	108	60
16-SEP.	32	164	71	86	56
19-SEP.	35	296	164	124	78
20-SEP.	36	729	368	201	103
21-SEP.	37	354	178	138	67
23-SEP.	39	245	96	79	27
26-SEP.	42	268	145	123	69
27-SEP.	43	569	253	154	92
28-SEP.	44	265	167	97	45
29-SEP.	45	111	86	39	24
30-SEP.	46	487	193	172	147
02-OCT.	49	107	62	52	46
04-OCT.	52	355	157	132	104
06-OCT.	53	302	108	101	62
Avg.		316	152	115	70
<hr/>					
FLOWRATE = 0.5 m ³ /h					
14-SEP.	30	177	73	108	60
16-SEP.	32	164	71	86	56
19-SEP.	35	296	164	124	78
20-SEP.	36	729	368	201	103
21-SEP.	37	354	178	138	67
23-SEP.	39	245	96	79	27
26-SEP.	42	268	145	123	69
27-SEP.	43	569	253	154	92
28-SEP.	44	265	167	97	45
29-SEP.	45	111	86	39	24
30-SEP.	46	487	193	172	147
02-OCT.	49	107	62	52	46
04-OCT.	52	355	157	132	104
06-OCT.	53	302	108	101	62
Avg.		316	152	115	70
<hr/>					
FLOWRATE = 0.7 m ³ /h					
07-OCT.	54	176	66	109	8
09-OCT.	56	447	204	290	161
11-OCT.	58	256	89	145	60
13-OCT.	60	287	128	175	63
16-OCT.	63	152	71	105	46
18-OCT.	65	360	104	225	53
20-OCT.	67	237	125	131	79
23-OCT.	70	249	162	79	27
25-OCT.	72	306	151	123	69
27-OCT.	74	348	127	181	92
30-OCT.	77	360	104	97	45
Avg.		289	121	151	64

COD of Anaerobic Fixed-Bed Reactor (Continued)

DATE	DAY-NR	INF.COD (mg/l)	EFF.COD (mg/l)	%EFF.(T)	%EFF.(F)
		Total	Filter	Total	Filter
FLOWRATE = 1.0 m3/h					
01-NOV.	78	137	105	88	61
02-NOV.	79	365	109	390	79
04-NOV.	81	549	138	326	94
07-NOV.	84	294	105	204	83
09-NOV.	86	487	193	376	98
11-NOV.	88	360	104	243	48
14-NOV.	91	302	96	209	67
15-NOV.	92	385	218	215	80
16-NOV.	93	161	89	103	66
Avg.		338	129	239	75
FLOWRATE = 2.0 m3/h					
06-JAN.	94	68	35	91	61
07-JAN.	95	392	384	208	233
09-JAN.	97	428	170	819	162
11-JAN.	99	714	221	418	263
13-JAN.	101	355	99	216	103
16-JAN.	104	877	206	517	162
18-JAN.	106	348	90	198	108
20-JAN.	108	210	83	140	62
Avg.		424	161	326	144
FLOWRATE = 4.0 m3/h					
21-JAN.	109	208	83	158	48
23-JAN.	111	212	30	154	33
24-JAN.	112	215	30	257	46
Avg.		212	48	190	42

COD of Anaerobic Upflow System Reactors

DATE	DAY-NR	INF.COD(mg/l)	EFF.COD (mg/l)	%EFF.(T)	%EFF.(F)
		TOTAL	FILTER	TOTAL	FILTER
FLOWRATE = 0.3 m³/h					
29-SEP.	1	111	20	94	15
02-OCT.	4	107	62	101	28
04-OCT.	6	355	157	225	104
06-OCT.	8	302	108	201	96
09-OCT.	11	447	204	174	106
11-OCT.	13	256	89	113	61
13-OCT.	15	287	128	71	43
16-OCT.	18	152	71	63	26
18-OCT.	20	360	104	119	68
20-OCT.	22	237	125	104	63
23-OCT.	25	249	162	98	28
25-OCT.	27	306	151	102	90
27-OCT.	29	348	127	131	54
30-OCT.	32	360	104	130	63
02-NOV.	34	365	109	127	82
04-NOV.	36	549	138	196	49
07-NOV.	39	294	105	76	31
09-NOV.	41	487	193	361	163
11-NOV.	43	360	104	130	63
12-NOV.	44	302	96	101	62
Avg.		312	118	136	65
FLOWRATE = 0.5 m³/h					
13-NOV.	45	308	127	141	74
15-NOV.	47	385	218	162	98
16-NOV.	48	161	89	65	40
18-NOV.	50	473	246	258	196
21-NOV.	53	291	129	86	39
23-NOV.	55	156	110	59	48
25-NOV.	57	538	188	261	113
28-NOV.	60	272	149	138	76
30-NOV.	62	201	79	116	57
01-DEC.	63	496	254	192	145
04-DEC.	66	385	218	139	116
06-DEC.	68	174	86	72	51
08-DEC.	70	389	157	113	94
11-DEC.	73	269	155	107	79
Avg.		321	158	136	88

COD of Anaerobic Upflow System Reactors
(Continued)

DATE	DAY-NR	INF.COD(mg/l)	EFF.COD (mg/l)		%EFF.(T)	%EFF.(F)
		TOTAL	FILTER	TOTAL	FILTER	
FLOWRATE = 0.7 m³/h						
12-DEC.	74	185	118	109	96	41
14-DEC.	76	471	200	174	104	63
16-DEC.	78	204	75	104	39	49
18-DEC.	80	472	104	184	64	61
20-DEC.	82	305	143	213	62	30
22-DEC.	84	392	164	121	88	69
25-DEC.	86	272	149	116	76	57
27-DEC.	89	678	113	144	73	79
29-DEC.	91	316	205	142	89	55
30-DEC.	93	180	115	74	59	58
02-JAN.	94	196	104	96	61	51
03-JAN.	97	225	142	103	87	54
Avg.		325	136	132	75	56
FLOWRATE = 1.0 m³/h						
06-JAN.	100	68	35	45	49	34
07-JAN.	101	392	384	177	49	55
09-JAN.	103	428	170	517	248	0
11-JAN.	105	714	221	164	44	77
13-JAN.	107	355	99	435	150	0
16-JAN.	110	877	206	308	206	65
18-JAN.	112	348	90	234	117	33
20-JAN.	114	210	83	145	56	31
22-JAN.	116	208	81	107	45	49
24-JAN.	118	215	30	111	26	48
26-JAN.	120	212	30	104	29	51
Avg.		366	130	213	93	40
FLOWRATE = 2.0 m³/h						
27-JAN.	121	196	74	205	69	0
28-JAN.	122	235	137	245	125	0
29-JAN.	123	298	108	386	120	0
31-JAN.	125	276	97	213	99	23
02-FEB.	127	321	105	309	106	4
04-FEB.	129	278	89	294	98	0
05-FEB.	130	265	76	229	65	14
Avg.		267	98	269	97	6

Appendix C

Suspended Solids and Settleable Solids

Suspended Solids and Settleable Solids of Fixed-bed Reactor

DATE	DAY-NR	SUSPENDED SOLIDS			SETTLEABLE SOLIDS EFFLUENT
		INF.	EFF.	%EFF.	
FLOWRATE = 0.3 m³/h					
16-AUG.	1	196	72	63	0.2
17-AUG.	2	87	23	74	0.2
19-AUG.	4	60	8	87	0.2
22-AUG.	7	108	49	55	0.1
24-AUG.	9	128	40	69	0.1
26-AUG.	11	89	19	79	0.1
29-AUG.	14	245	49	80	0.2
31-AUG.	16	99	21	79	0.1
02-SEP.	18	226	85	62	0.2
05-SEP.	21	76	13	83	0.1
07-SEP.	23	114	8	93	0.1
09-SEP.	25	106	63	41	0.2
12-SEP.	28	94	47	50	0.1
Avg.		125	38	70	0.1
FLOWRATE = 0.5 m³/h					
14-SEP.	30	99	54	45	0.0
16-SEP.	32	68	56	18	0.0
19-SEP.	35	112	39	65	0.1
20-SEP.	36	247	92	63	0.2
21-SEP.	37	114	69	39	0.1
23-SEP.	39	129	58	55	0.0
26-SEP.	42	103	62	40	0.1
27-SEP.	43	195	54	72	0.1
28-SEP.	44	136	66	51	0.1
29-SEP.	45	52	26	50	0.0
30-SEP.	46	228	34	85	0.0
02-OCT.	49	59	8	86	0.0
04-OCT.	52	201	28	86	0.1
06-OCT.	53	217	36	83	0.1
Avg.		140	49	60	0.1
FLOWRATE = 0.7 m³/h					
07-OCT.	54	81	69	15	0.2
09-OCT.	56	165	112	32	0.6
11-OCT.	58	143	87	39	0.3
13-OCT.	60	168	140	17	0.4
16-OCT.	63	86	73	15	0.2
18-OCT.	65	219	130	41	1.2
20-OCT.	67	80	66	18	0.3
23-OCT.	70	79	52	34	0.1
25-OCT.	72	109	46	58	0.2
27-OCT.	74	171	68	60	0.3
30-OCT.	77	196	55	72	0.1
Avg.		136	82	36	0.4

Suspended Solids and Settleable Solids of Fixed-bed Reactor
 (Continued)

DATE	DAY-NR	SUSPENDED SOLIDS			SETTLEABLE SOLIDS EFFLUENT
		INF.	EFF.	%EFF.	
FLOWRATE = 1.0 m³/h					
01-NOV.	78	26	64	0	4.1
02-NOV.	79	209	283	0	17.0
04-NOV.	81	311	246	21	14.2
07-NOV.	84	186	174	6	10.3
09-NOV.	86	188	240	0	12.2
11-NOV.	88	127	139	0	6.9
14-NOV.	91	114	121	0	6.1
15-NOV.	92	99	116	0	4.9
16-NOV.	93	86	75	13	1.4
Avg.		150	162	4	8.6
FLOWRATE = 2.0 m³/h					
06-JAN.	94	60	96	0	0.1
07-JAN.	95	476	180	62	0.2
09-JAN.	97	504	244	52	1
11-JAN.	99	640	208	68	1.2
13-JAN.	101	492	176	64	0.5
16-JAN.	104	1452	200	86	0.1
18-JAN.	106	322	216	33	0.2
20-JAN.	108	1868	148	92	0.3
Avg.		727	184	57	0.5
FLOWRATE = 4.0 m³/h					
21-JAN.	109	208	64	69	8.6
23-JAN.	111	225	192	15	0.3
24-JAN.	112	217	128	42	0.1
Avg.		216.5	128	42	3

Suspended Solids and Settleable Solids of RAUS Reactor

DATE	DAY-NR	SUSPENDED SOLIDS			SETTLEABLE SOLIDS EFFLUENT
		INF.	EFF.	%EFF.	
FLOWRATE = 0.3 m³/h					
29-SEP.	1	52	48	7.69	0.0
02-OCT.	4	59	45	23.73	0.0
04-OCT.	6	201	69	65.67	0.1
06-OCT.	8	217	65	70.05	0.1
09-OCT.	11	165	47	71.52	0.1
11-OCT.	13	143	38	73.43	0.0
13-OCT.	15	168	64	61.90	0.1
16-OCT.	18	86	41	52.33	0.0
18-OCT.	20	219	52	76.26	0.1
20-OCT.	22	80	29	63.75	0.0
23-OCT.	25	79	46	41.77	0.0
25-OCT.	27	109	20	81.65	0.0
27-OCT.	29	171	44	74.27	0.0
30-OCT.	32	196	28	85.71	0.0
02-NOV.	34	209	36	82.78	0.0
04-NOV.	36	311	58	81.35	0.1
07-NOV.	39	186	18	90.32	0.0
09-NOV.	41	188	72	61.70	0.2
11-NOV.	43	127	31	75.59	0.0
12-NOV.	44	114	24	78.95	0.0
Avg.		154	44	66	0.04
FLOWRATE = 0.5 m³/h					
13-NOV.	45	99	56	43.43	0.2
15-NOV.	47	86	42	51.16	0.2
16-NOV.	48	103	57	44.66	0.2
18-NOV.	50	83	47	43.37	0.3
21-NOV.	53	54	33	38.89	0.2
23-NOV.	55	368	128	65.22	3.1
25-NOV.	57	82	47	42.68	0.2
28-NOV.	60	280	88	68.57	0.3
30-NOV.	62	219	67	69.41	0.4
01-DEC.	63	86	39	54.65	0.3
04-DEC.	66	65	29	55.38	0.2
06-DEC.	68	96	55	42.71	0.2
08-DEC.	70	89	23	74.16	0.5
11-DEC.	73	208	89	57.21	0.3
Avg.		137	57	54	0.5

Suspended Solids and Settleable Solids of RAUS Reactor
(Continued)

DATE	DAY-NR	SUSPENDED SOLIDS			SETTLEABLE SOLIDS EFFLUENT	
		INF.	EFF.	%EFF.		
<hr/>						
		FLOWRATE = 0.7 m ³ /h				
12-DEC.	74	174	60	65.52	3.7	
14-DEC.	76	484	112	76.86	12.1	
16-DEC.	78	109	164	0.00	11.3	
18-DEC.	80	152	49	67.76	3.3	
20-DEC.	82	106	38	64.15	2.9	
22-DEC.	84	496	57	88.51	4.2	
25-DEC.	86	81	46	43.21	3.1	
27-DEC.	89	543	193	64.46	2.8	
29-DEC.	91	355	146	58.87	2.2	
30-DEC.	93	201	104	48.26	0.7	
02-JAN.	94	187	83	55.61	0.5	
03-JAN.	97	69	28	59.42	0.3	
Avg.		246	90	57.72	3.9	
<hr/>						
		FLOWRATE = 1.0 m ³ /h				
06-JAN.	100	60	29	51.67	0.2	
07-JAN.	101	476	253	46.85	0.3	
09-JAN.	103	504	287	43.06	0.2	
11-JAN.	105	640	160	75.00	0.1	
13-JAN.	107	492	152	69.11	5.5	
16-JAN.	110	1452	364	74.93	0.3	
18-JAN.	112	322	304	5.59	2.0	
20-JAN.	114	1868	403	78.43	0.3	
22-JAN.	116	868	216	75.12	1.2	
24-JAN.	118	208	64	69.23	0.2	
26-JAN.	120	225	148	34.22	0.5	
Avg.		647	216	56.66	1.0	
<hr/>						
		FLOWRATE = 2.0 m ³ /h				
27-JAN.	121	137	77	43.80	0.2	
28-JAN.	122	503	205	59.24	0.1	
29-JAN.	123	809	487	39.80	0.1	
31-JAN.	125	533	204	61.73	0.3	
02-FEB.	127	665	321	51.73	0.1	
04-FEB.	129	541	245	54.71	0.2	
05-FEB.	130	741	349	52.90	0.1	
Avg.		561	270	51.99	0.16	
<hr/>						

pH and Temperature of Fixed-bed Reactor

DATE	DAY-NR	pH		TEMPERATURE	
		INF.	EFF.	INF.	EFF.
FLOWRATE = 0.3 m³/h					
16-AUG.	1	7.82	6.98	29.8	30.0
17-AUG.	2	7.64	7.08	29.6	29.9
19-AUG.	4	7.80	7.09	29.4	30.2
22-AUG.	7	7.54	6.86	29.8	30.6
24-AUG.	9	7.63	6.98	31.1	30.6
26-AUG.	11	7.72	6.99	31.9	30.5
29-AUG.	14	7.57	6.94	32.6	30.6
31-AUG.	16	7.69	7.08	32.2	30.2
02-SEP.	18	7.54	6.85	31.2	29.9
05-SEP.	21	7.72	6.88	30.1	30.2
07-SEP.	23	7.58	6.83	32.4	30.0
09-SEP.	25	7.64	7.08	29.6	29.9
12-SEP.	28	7.54	6.88	31.2	30.0
Avg.		7.65	6.96	30.8	30.2
FLOWRATE = 0.5 m³/h					
14-SEP.	30	7.57	7.20	32.6	30.2
16-SEP.	32	7.65	7.15	31.8	29.7
19-SEP.	35	7.69	6.98	32.1	30.0
20-SEP.	36	7.55	7.10	31.0	29.4
21-SEP.	37	7.68	7.03	31.6	30.0
23-SEP.	39	7.95	7.15	31.3	29.4
26-SEP.	42	7.73	7.09	31.4	29.8
27-SEP.	43	7.41	7.11	31.2	29.4
28-SEP.	44	7.94	6.90	30.8	29.1
29-SEP.	45	7.66	7.15	29.7	29.1
30-SEP.	46	7.53	7.25	29.8	29.6
02-OCT.	49	7.92	7.05	31.2	30.1
04-OCT.	52	7.43	6.91	31.3	30.2
06-OCT.	53	7.65	7.15	30.6	29.3
Avg.		7.67	7.09	31.2	29.7
FLOWRATE = 0.7 m³/h					
07-OCT.	54	7.93	7.05	31.2	29.4
09-OCT.	56	7.96	7.09	32.8	29.5
11-OCT.	58	7.56	7.11	30.9	29.8
13-OCT.	60	7.72	7.06	33.7	29.9
16-OCT.	63	7.75	7.07	31	29.6
18-OCT.	65	7.59	7.09	30.7	29.3
20-OCT.	67	7.61	6.98	31.3	29.7
23-OCT.	70	7.74	7.14	32.4	30
25-OCT.	72	7.53	7.12	32.1	29.7
27-OCT.	74	7.58	7.1	31.8	29.6
30-OCT.	77	7.66	7.06	30.7	29.6
Avg.		7.69	7.08	31.7	29.6

pH and Temperature of Fixed-bed Reactor
(Continued)

DATE	DAY-NR	pH		TEMPERATURE	
		INF.	EFF.	INF.	EFF.
FLOWRATE = 1.0 m³/h					
01-NOV.	78	7.49	7.05	29.9	29.3
02-NOV.	79	7.86	7.07	30.7	29.6
04-NOV.	81	7.96	7.09	31.2	29.7
07-NOV.	84	7.52	7.01	31.9	29.9
09-NOV.	86	7.59	7	31.3	29.0
11-NOV.	88	7.65	6.98	32.1	30.1
14-NOV.	91	7.63	6.95	31.6	29.4
15-NOV.	92	7.59	7.12	31.7	29.8
16-NOV.	93	7.72	7.2	32.1	29.9
Avg.		7.67	7.05	31.4	29.6
FLOWRATE = 2.0 m³/h					
06-JAN.	94	7.73	7.13	31.1	30.2
07-JAN.	95	7.69	7.18	30.6	29.9
09-JAN.	97	7.64	7.25	30.7	30.4
11-JAN.	99	7.73	7.26	31.7	31.
13-JAN.	101	7.71	7.16	30.5	30.2
16-JAN.	104	7.76	7.18	30	29.8
18-JAN.	106	7.72	7.09	30.6	30.5
20-JAN.	108	7.69	7.1	30.8	30.3
Avg.		7.71	7.17	30.8	30.3
FLOWRATE = 4.0 m³/h					
21-JAN.	109	7.78	7.18	31.3	30.8
23-JAN.	111	7.73	7.11	30.7	30.4
24-JAN.	112	7.65	7.06	30.9	30.6
		7.72	7.12	31.0	30.6

ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย

pH and Temperature of RAUS Reactors

DATE	DAY-NR	pH		TEMPERATURE	
		INF.	EFF.	INF.	EFF.
FLOWRATE = 0.3 m³/h					
29-SEP.	1	7.66	6.96	29.7	29.1
02-OCT.	4	7.92	7.01	31.2	29.4
04-OCT.	6	7.43	7.00	31.3	29.9
06-OCT.	8	7.65	7.01	30.6	29.2
09-OCT.	11	7.96	7.03	32.5	29.6
11-OCT.	13	7.56	7.14	31.2	29.4
13-OCT.	15	7.72	7.12	33.7	29.9
16-OCT.	18	7.75	7.01	32.6	29.8
18-OCT.	20	7.59	7.04	30.9	29.5
20-OCT.	22	7.61	7.02	31.6	29.8
23-OCT.	25	7.74	7.01	32.4	29.9
25-OCT.	27	7.53	7.13	31.9	29.8
27-OCT.	29	7.58	7.20	30.7	29.7
30-OCT.	32	7.66	7.05	29.8	29.1
02-NOV.	34	7.86	7.03	29.6	29.2
04-NOV.	36	7.96	7.01	29.7	29.0
07-NOV.	39	7.52	7.15	29.9	29.3
09-NOV.	41	7.59	7.20	29.0	29.0
11-NOV.	43	7.65	7.03	30.1	29.4
12-NOV.	44	7.91	7.05	29.4	29.0
Avg.		7.69	7.06	30.9	29.5
FLOWRATE = 0.5 m³/h					
13-NOV.	45	7.46	6.96	31.7	29.7
15-NOV.	47	7.59	7.01	31.4	29.4
16-NOV.	48	7.72	7.03	30.8	29.6
18-NOV.	50	7.85	7.17	31.3	29.8
21-NOV.	53	7.66	7.14	30.2	29.8
23-NOV.	55	7.59	7.01	30.1	29.1
25-NOV.	57	7.57	6.99	29.9	29.1
28-NOV.	60	7.62	7.03	30.4	29.2
30-NOV.	62	7.68	7.05	30.5	29.3
01-DEC.	63	7.93	7.18	32.1	30.0
04-DEC.	66	7.82	7.09	30.9	29.5
06-DEC.	68	7.88	7.15	31.1	29.7
08-DEC.	70	7.80	6.96	30.8	29.9
11-DEC.	73	7.64	7.01	31.4	29.8
Avg.		7.70	7.06	30.9	29.6

pH and Temperature of RAUS Reactors
(Continued)

DATE	DAY-NR	PH		TEMPERATURE	
		INF.	EFF.	INF.	EFF.
FLOWRATE = 0.7 m³/h					
12-DEC.	74	7.49	7.04	30.9	29.9
14-DEC.	76	7.76	7.18	32.1	29.9
16-DEC.	78	7.69	7.09	31.5	29.8
18-DEC.	80	7.55	7.06	31.0	29.3
20-DEC.	82	7.62	7.13	31.2	29.8
22-DEC.	84	7.83	7.19	29.9	29.4
25-DEC.	86	7.61	7.05	31.3	29.6
27-DEC.	89	7.58	7.01	31.8	29.9
29-DEC.	91	7.86	7.03	31.1	29
30-DEC.	93	7.83	7.05	30.6	28.9
02-JAN.	94	7.79	7.1	30.7	28.8
03-JAN.	97	7.86	7.11	31.7	29
Avg.		7.71	7.09	31.2	29.4
FLOWRATE = 1.0 m³/h					
06-JAN.	100	7.71	7.08	30.5	28.9
07-JAN.	101	7.76	7.24	30	29.1
09-JAN.	103	7.72	6.94	30.6	29.3
11-JAN.	105	7.69	7.23	30.8	29.5
13-JAN.	107	7.59	7.22	31.3	29.4
16-JAN.	110	7.72	7.09	30.7	29
18-JAN.	112	7.64	7.13	30.9	29.3
20-JAN.	114	7.73	7.15	30.8	29.1
22-JAN.	116	7.74	7.19	30.6	29.2
24-JAN.	118	7.65	7.15	30.7	29
26-JAN.	120	7.83	7.2	30.5	29.4
Avg.		7.71	7.15	30.7	29.2
FLOWRATE = 2.0 m³/h					
27-JAN.	121	7.71	7.26	30.3	29.1
28-JAN.	122	7.78	7.25	30.2	28.9
29-JAN.	123	7.73	7.28	30	29
31-JAN.	125	7.65	7.35	31.1	29.5
02-FEB.	127	7.7	7.24	30.8	29.4
04-FEB.	129	7.81	7.18	30.4	29.2
05-FEB.	130	7.69	7.16	30.3	29.4
Avg.		7.72	7.25	30.4	29.2

Appendix D
Characteristics of Methanogenic Bacteria

Summary of characteristics of methanogenic archaebacteria, order Methanobacteriales*

Archaeobacteria	Morphology	Substrates	G + C (mol%)	Temp optimum (°C)	pH optimum	Cell envelope composition	Major membrane isoprenoid	Reference(s)
Family Methanobacteriaceae								
<i>Methanobacterium formicum</i>	Rod	H ₂ , formate	40.7	37	7.0	Pseudomurein	C ₂₀ + C ₂₀	12
<i>M. brevicellum</i>	Rod	H ₂	32.7	38	7.0	Pseudomurein	C ₂₀ + C ₂₀	12
<i>M. thermoadaptrophicum</i>	Rod	H ₂	49.7	63-70	7.2-7.6	Pseudomurein	C ₂₀ + C ₂₀	546
<i>M. wulfel</i>	Rod	H ₂	61	55-65	7.0-7.5	Pseudomurein	ND*	517
<i>M. thermoaggregans</i>	Rod	H ₂	42	65	7.0-7.5	ND	ND	32
<i>M. thermaoaliphilum</i>	Rod	H ₂	38.8	60	7.5-8.5	ND	ND	33
<i>Methanobrevibacter ruminantium</i>	Rod	H ₂ , formate	30.6	38	7.2	Pseudomurein	C ₂₀ + C ₂₀	431
<i>M. smilii</i>	Rod	H ₂ , formate	31	38	6.9-7.4	Pseudomurein	C ₂₀ + C ₂₀	325
<i>M. urceolophilus</i>	Rod	H ₂	29	30-37	7.5-8.0	Pseudomurein	C ₂₀ + C ₂₀	544
<i>Methanospaera stutmanniae</i>	Coccus	H ₂ + methanol	25.8	36-40	6.5-6.9	Pseudomurein	ND	323, 324
Family Methanothermaceae								
<i>Methanothermus fervidus</i>	Rod	H ₂	33	63	6.5	Pseudomurein + protein	C ₂₀	446

Summary of characteristics of methanogenic archaebacteria, order Methanococcales, family Methanococcaceae*

Archaeobacteria	Morphology	Substrates	G + C (mol%)	Temp optimum (°C)	pH optimum	Cell envelope composition	Major membrane isoprenoid	Reference(s)
<i>Methanococcus vannielii</i>	Coccus	H ₂ , formate	32.5	36-40	7.0-9.0	Protein	C ₂₀ , Ir C ₂₀	12
<i>M. vultus</i>	Coccus	H ₂ , formate	29.6	32-40	6.7-7.4	Protein	C ₂₀	503
<i>M. murielensis</i>	Coccus	H ₂ , formate	33.4	38	6.8-7.2	Protein	ND*	208
<i>M. delttii</i>	Coccus	H ₂ , formate	33.6	37	ND	ND	ND	56
<i>M. thermolithotrophicus</i>	Coccus	H ₂ , formate	33.6	63	6.5-7.5	Protein	C ₂₀	179
<i>M. jannaschii</i>	Coccus	H ₂	31	85	6.0	Protein	Cyclic diether, C ₂₀ + C ₂₀	55, 207

Summary of characteristics of methanogenic archaebacteria, order Methanomicrobiales**

Archaeobacteria	Morphology	Substrates	G + C (mol%)	Temp optimum (°C)	pH optimum	Cell envelope composition	Major membrane isoprenoid	Reference
Family Methanomicrobium								
<i>Methanomicrobium mobile</i>	Rod	H ₂ , formate	48.8	40	6.1-6.9	Protein	C ₂₀ + C ₂₀	337
<i>M. puynteri</i>	Rod	H ₂	44.9	40	6.5-7.0	ND	ND	373
<i>Methanogenium curreci</i>	Coccus	H ₂ , formate	51.6	20-23	6.8-7.3	Protein	C ₂₀ + C ₂₀	382
<i>M. murielense</i>	Coccus	H ₂ , formate	61.2	20-23	6.2-6.6	Glycoprotein	C ₂₀ + C ₂₀	382
<i>M. oleum</i>	Coccus	H ₂	54.4	37	ND	ND	ND	56
<i>M. fallii</i>	Coccus	H ₂ , formate	54	40	7.0	Glycoprotein	ND	539
<i>M. limicola</i>	Planes	H ₂ , formate	47.5	40	7.0	Glycoprotein	C ₂₀ + C ₂₀	513
<i>M. thermophilicum</i>	Coccus	H ₂ , formate	59	55	7.0	ND	C ₂₀ + C ₂₀	376
<i>M. sellonii</i>	Coccus	H ₂ , formate	49.2	57	7.0-7.5	Protein	ND	157
<i>Methanospirillum hungaricum</i>	Curved rod	H ₂ , formate	45	30-37	6.6-7.4	Protein, sheath	C ₂₀ + C ₂₀	122
Family Methanosaetae								
<i>Methanosaeta barkeri</i>	Coccus, packets	H ₂ , Me, MeNH ₂ , Ac	39	35	7.0	HPS + protein	C ₂₀ + C ₂₁	12, 168
<i>M. mazei</i>	Coccus	H ₂ , Me, MeNH ₂ , Ac	42	40	6.0-7.0	HPS	C ₂₀ + C ₂₁	301
<i>M. thermophila</i>	Coccus	H ₂ , Me, MeNH ₂ , Ac	42	50	6.0-7.0	HPS	ND	559, 561
<i>M. acetylivorans</i>	Coccus	Me, MeNH ₂ , Ac	42	40	6.5-7.0	Protein	ND	433
<i>Methanococcoides methylutens</i>	Coccus	Me, MeNH ₂	42	35	7.0-7.5	Protein	C ₂₀	434
<i>Methanobolbus lindnerius</i>	Coccus	Me, MeNH ₂	40	25	6.5	Glycoprotein	C ₂₀ + C ₂₁	259
<i>Methanococcus halophilus</i>	Coccus	Me, MeNH ₂	ND	26-36	6.5-7.4	ND	ND	548
<i>Halomethanococcus maki</i>	Coccus	Me, MeNH ₂	48.5	35	7.5	ND	ND	354
<i>Methanotheria soehngenii</i>	Rod	Ac	51.9	37	7.4-7.8	Protein, sheath	C ₂₀	183
<i>Methanotheria sp.</i>	Rod	H ₂ , Ac	ND	60	ND	ND	ND	537

* Also refer to references 12, 426, 504, and 514 and consult text. Abbreviations: ND, Not determined; Me, methanol; MeNH₂, methylamine; Ac, acetate; HPS, heteropolysaccharide.

VITA

The author, Miss Araya Surin, was born on December 23, 1962 in Lampang province, Thailand. She graduated with a bachelor's degree of Environmental Engineering from Chiang Mai University in 1985. She then worked with the Public Works Department, Ministry of Interior. After one year of being an engineer for sewage network she changed her career to become a lecturer at the Institute of Technical and Vocational Education, Chiang Mai campus. After teaching for almost 2 years, she left her job to further her postgraduate study in Environmental Engineering at Graduate School, Chulalongkorn University. She also had a few years experience with a private company, Envirtech Consultants, Co.Ltd, during her first year of study at Chulalongkorn University.



ศูนย์วิทยทรัพยากร
จุฬาลงกรณ์มหาวิทยาลัย