

CHAPTER IV


RESULTS AND DISCUSSION

4.1 Design Case

4.1.1 The Collected Data and Heat Exchanger and Stream Data Modeling

After the heat exchangers and streams were simulated to check the phase change temperature (dew point and bubble point) and the enthalpy change from sensible heat and latent heat. The result from the simulation of ProII and the calculation of latent heat are shown in Table 4.1. In this study, 29 hot and 21 cold streams were selected. The location and information of each stream are described in Appendix A-1.

The example of calculation of latent heat for stream H2 is shown below: (note that the phase changes occur in stream from mixed phases to liquid at the bubble point temperature).



Latent heat = total heat – sensible heat (assume that there is no heat loss)

= overall duty of heat exchanger 100-E1 and 100-EA2

$$-mC_{p_{avg,liq}}(T_{bubble} - T_{out})$$

$$= 8.95 \times 10^3 - (132.558 \text{ MW/}^\circ\text{C}) \times (111.023 - 107)^\circ\text{C}$$

$$= 23.227 \text{ MW}$$

The heat exchanger network design or modification is usually done on grid diagram because of its simplicity. For the design case of existing plant, the grid diagram can be constructed by using the above data as shown in Figure 4.1.

Table 4.1 The result from design case simulation of Pro II and calculation of latent heat (hot streams)

stream	stream in		stream out		phase change	T _{dew} C	T _{bubble} C	flowrate kg/hr	Cp in kWhr/kgC	Cp out kWhr/kgC	Cp avg kWhr/kgC	mCp kW/C	Tin C	Tout C	Temp change for sensible heat (C)	total duty MW	sensible heat MW	latent heat MW
	name	phase	name	phase														
H1	346	liq	351	liq	✗	-	-	71144	0.00086	0.00061	0.00074	52.44	239	49	239-49	8.95	-	-
H2	306	mixed	310	liq	✓	-	111	220951	0.00057	0.00063	0.00060	132.56	149	107	111.022-107	23.76	0.533	23.227
H3	540	liq	544	liq	✗	-	-	19333	0.00117	0.00073	0.00095	18.34	109.00	38.00	109-38	1.19	-	-
H4	606	vapor	604	mixed	✓	60.89	-	3566	0.00069	0.00089	0.00079	2.81	64	40	64-60.887	0.23	0.009	0.221
H5	605	mixed	525	mixed	✓	-	-	792	0.00067	0.00082	0.00075	0.59	38	23	-	0.04	-	0.040
H6	511	liq	565	liq	✗	-	-	35173	0.00079	0.00063	0.00071	24.88	116	38	116-38	1.98	-	-
H7	499	vapor	498	mixed	✓	53.93	-	45847	0.00056	0.00079	0.00068	31.06	56	47	56-53.925	4.31	0.064	4.246
H8	006		008		✗	-	-	242137	0.00084	0.00061	0.00072	175.31	220	60	220-60	27.07	-	-
H9	131	vapor	132	mixed	✓	276.7	-	148267	0.00081	0.00068	0.00074	110.31	343	131	343-276.642	32.22	7.317	24.903
H10	136	mixed	137	mixed	✓	-	-	153252	0.00067	0.00059	0.00063	96.04	121	49	-	8.04	-	8.040
H11	307	vapor	309	mixed	✓	51.45	-	21174	0.00093	0.00083	0.00088	18.67	162	50	162-51.449	3.21	2.064	1.146
H12	341	liq	399	liq	✗	-	-	146465	0.00084	0.00064	0.00074	108.10	222	109	222-109	14.45	-	-
H13	194	vapor	195	vapor	✗	-	-	208.9	0.00097	0.00072	0.00085	0.18	524	180	524-179.9	0.06	-	-
H14	167	mixed	181	mixed	✓	-	-	176380	0.00069	0.00090	0.00080	140.33	103.2	48.5	-	15.07	-	15.070
H15	1204	vapor	1212	mixed	✓	61.71	-	22648	0.00134	0.00128	0.00131	29.71	132.9	55	132.9-61.71	2.32	2.115	0.205
H16	1122	vapor	1123	mixed	✓	63.57	-	4080	0.00105	0.00128	0.00116	4.75	111.8	8	111.8-63.567	0.60	0.229	0.371
H17	1164	mixed	1165	mixed	✓	-	-	153530	0.00095	0.00098	0.00096	147.52	46.86	37.9	-	1.09	-	1.087
H18	1214	mixed	1215	mixed	✓	-	-	137680	0.00118	0.00126	0.00122	168.15	56.19	37.8	-	1.87	-	1.873
H19	1254	vapor	1265	mixed	✓	44.58	-	2519	0.00168	0.00167	0.00168	4.22	59.54	37.8	59.54-44.584	0.09	0.063	0.029
H20	1474	liq	1469	liq	✗	-	-	126970	0.00075	0.00059	0.00067	85.09	211.7	103	211.7-103.4	9.77	-	-
H21	1406	vapor	1409	mixed	✓	65.2	-	27055	0.00058	0.00075	0.00067	18.02	66.75	38.3	66.75-65.202	2.67	0.028	2.642
H22	1411	vapor	-	mixed	✓	37.32	-	985.8	0.00056	0.00065	0.00061	0.60	37.78	8	37.78-37.323	0.08	0.000	0.080
H23	-	-	-	-	✗	-	-	60062	0.00127	0.00126	0.00127	76.00	40	38	40-38	0.15	-	-
H24	-	-	-	-	✗	-	-	2750.4	0.00119	0.00111	0.00115	3.16	135	55	135-55	0.25	-	-
H25	-	-	-	-	✗	-	-	525.6	0.00125	0.00103	0.00114	0.60	295	66	295-66	0.14	-	-
H26	-	-	-	-	✗	-	-	309.6	0.00152	0.00124	0.00138	0.43	477	66	477-66	0.18	-	-
H27	-	vapor	-	vapor	✗	-	-	34157	0.00032	0.00032	0.00032	10.94	517	482	517-482	0.38	-	-
H28	1154	vapor	1162	mixed	✓	69.39	-	29600	0.00012	0.00111	0.00061	18.20	131	56.1	131-69.391	2.65	1.121	1.529
H29	170	vapor	173	liq	✓	94.27	68.66	113987	0.00058	0.00070	0.00064	72.70	97	52	97-94.268 69.391-52	13.11	1.463	11.647

Table 4.1 (Continued) The result from design case simulation of Pro II and calculation of latent heat (cold streams)

stream	stream in		stream out		phase change	T _{dew} C	T _{bubble} C	flowrate kg/hr	Cp in kWhr/kgC	Cp out kWhr/kgC	Cp avg kWhr/kgC	mCp kW/C	Tin C	Tout C	Temp change for sensible heat (C)	total duty MW	sensible heat MW	latent heat MW
	name	phase	name	phase														
C1	131	liq	138	mixed	✓	-	192.3	160237	0.00077	0.00074	0.00076	121.11	188	201	188-192.322	16.40	0.523	15.877
C2	103	liq	110	liq	✗	-	-	265176	0.00057	0.00072	0.00065	172.10	38	143	38-143	18.18	-	-
C3	517	liq	513	liq	✗	-	-	19690	0.00074	0.00086	0.00080	15.80	43	78	43-78	0.54	-	-
C4	525	vapor	527	vapor	✗	-	-	357	0.00066	0.00052	0.00059	0.21	24	42	24-42	0.00	-	-
C5	302	liq	305	liq	✗	-	-	49679	0.00070	0.00075	0.00073	36.02	52	76	52-76	0.86	-	-
C6	507	liq	508	mixed	✓	-	116	207949	0.00079	0.00074	0.00076	158.75	116	118	116-116.008	5.49	0.001	5.489
C7	-	-	-	-	✗	-	-	242137	0.00076	0.00084	0.00080	193.95	184.5	220	184.5-220	8.24	-	-
C9	-	-	002	-	✗	-	-	241836	0.00055	0.00076	0.00066	158.84	36.8	189	36.8-188.7	24.17	-	-
C10	112	liq	115	vapor	✓	289	263.5	148267	0.00058	0.00082	0.00070	103.80	63	339	63-263.482 288.984-339	38.73	20.80978 5.191599	12.729
C11	151	mixed	306	mixed	✓	-	-	146965	0.00057	0.00072	0.00064	94.38	49	157	-	10.30	-	10.300
C12	334	liq	338	mixed	✓	-	222	261020	0.00084	0.00073	0.00078	204.64	222	230	-	6.60	-	6.600
C13	190	vapor	193	vapor	✗	-	-	263.6	0.00105	0.00123	0.00114	0.30	111.8	316	111.8-315.6	0.06	-	-
C14	1720	liq	1405-1420	liq	✗	-	-	23928	0.00067	0.00080	0.00073	17.57	86	162	86-162	1.33	-	-
C15	1438	liq	1420	liq	✗	-	-	131800	0.00050	0.00065	0.00058	76.02	37	154	37-154.1	9.77	-	-
C16	1449	liq	1451	mixed	✓	-	213.7	144620	0.00075	0.00066	0.00070	101.70	211.7	228	211.7-213.715	7.37	0.205	7.165
C17	-	-	-	-	✗	-	-	n/a	n/a	n/a	n/a	n/a	38	149	38-149	9.78	-	-
C18	-	-	-	-	✗	-	-	n/a	n/a	n/a	n/a	n/a	38	149	38-149	0.08	-	-
C19	-	vapor	-	vapor	✗	-	-	679.68	0.00030	0.00031	0.00031	0.21	420	539	420-539	0.03	-	-
C20	-	vapor	-	vapor	✗	-	-	34155	0.00032	0.00032	0.00032	10.86	452	482	452-482	0.32	-	-
C21	-	vapor	-	vapor	✗	-	-	1336.7	0.00028	0.00031	0.00029	0.39	38	577	38-577	0.21	-	-
C22	-	-	-	-	✗	-	-	244.8	n/a	n/a	n/a	0.40	38	570	38-570	0.21	-	-




Figure 4.1 Grid diagram for design case of existing plant.

4.1.2 Energy Target

The problem table analysis and grand composite curves at any minimum approach temperatures had been done as in the procedure in section 3.4. The data extracted from grand composite curve will give the minimum utility requirement which results in minimum total cost and minimum heat exchanger capital investment cost at any ΔT_{\min} . The Problem Table Algorithm for various ΔT_{\min} is shown in Appendix B and the result of PTA is shown in Table 4.2.

Table 4.2 Result of PTA at various ΔT_{\min}

ΔT_{\min} C	$Q_{H\min}$ MW	$Q_{C\min}$ MW	pinch C
5	30.507	47.712	197.322
10	33.54	50.751	202.322
20	39.55	56.741	212.322
30	44.578	61.789	220.000
40	48.918	66.123	222.000
70	64.9376	82.243	149.000

The design case of existing plant uses 57.055 MW of hot utility and 74.36 MW of cold utility in the process. These values of both utilities tell that ΔT_{\min} of the process is 58.91 °C. The ΔT_{\min} of this process when comparing with the similar process in many literatures which is about 10-20 °C (Linnhoff, 1998) is very high. This can be conclude that the utility usage in the process is too high and can be reduced by recovering process to process energy.

4.1.3 Area Target

After the utility demand for global ΔT_{\min} is carried out, the area requirement which is less than the existing one ($\Delta T_{\min} < \Delta T_{\min, \text{existing}}$) is required for doing retrofit. In retrofits, these plots only consider heat recovery area, i.e., process-to-process exchangers. The area of heat transfer with utilities is not considered.

The surface area of over all and each of existing heat exchanger is shown in Table 4.3. The hot and cold composite curves for calculating minimum area

at various ΔT_{\min} are shown in Figure 4.2. The procedure to construct the curves as in section 3.5 is shown in Appendix C-1. The result from this analysis is in Table 4.4.

Table 4.3 Surface area of existing heat exchanger in the process

HEX	Stream	surface area m ²
100-E1	H2	661
	C2	
100-E2/2A	H1	202.700
	C2	
100-E4	H6	76.700
	C5	
100-E6	H3	32.700
	C3	
110-E1A-D	H8	2768.000
	C9	
150-E1A-H	H9	1944.000
	C10	
150-E2AB	H12	231.600
	C11	
200-E2	H13	6.977
	C13	
200-E6A/B	H20	265.400
	C15	
total area		6189.077 m ²

Table 4.4 Result from targeting area at various ΔT_{\min}

ΔT_{\min} C	A_{ideal} m ²
5	11197.47
10	8711.433
20	6147.266
30	4891.984
40	4120.343
58.915 (existing case)	2700.348




Figure 4.2 Hot and cold composite curves at various ΔT_{\min} .

4.1.4 Setting Retrofit Targets

First, the area efficiency of the existing network is calculated and a path for retrofitting is established on an area-energy plot. Next, the area energy plot is converted to an investment-savings plot and the payback period line used to determine the target ΔT_{\min} .

Step1. Calculation of Area Targets for Various Energy Levels and Area Efficiency of Existing network

The existing HEN has an area efficiency of 0.436309, where the existing area (A_{existing}) and target area (A_{ideal}) for the existing energy recovery are 6187.01 and 2700.35 m² respectively.

Step 2. Calculation of the Retrofit Curve

The utility demands and area requirement for each global ΔT_{min} which were calculated in section 4.1.2 and 4.1.3 are concluded in Table 4.5 and the area-energy plot is shown in Figure 4.3.

Table 4.5 Area-energy data for various ΔT_{min}

ΔT_{min} C	$Q_{\text{cu,min}}$ kW	$Q_{\text{hu,min}}$ kW	A_{ideal} m ²	$A_{\text{max,retr}}$ $\Delta\alpha=1$	$A_{\text{max,retr}}$ $\Delta\alpha=0.4365$
5	47712.2	30506.92	11197.47	14686.2	25664.102
10	50751.4	33539.8	8711.4331	12200.16	19966.216
20	56741.3	39549.44	6147.2659	9635.995	14089.259
30	61788.9	44577.71	4891.9839	8380.713	11212.209
40	66123.8	48666	4120.343	7609.072	9443.6421
58.915	78926.9	57055.27	2700.348	6189.077	6189.077




Figure 4.3 Retrofit curve on area-energy plot.

Step3. Calculation of Energy Savings and Extra Area Required

Before calculating of the energy saving, the utility usage for multiple utility levels is required and Problem Table Analysis will be very useful in this step as shown in Appendix D-1. The data of target utility usage for various ΔT_{min} was concluded in the Table 4.6 where

Annual utilities cost in \$(/kWyr) for :	Medium Pressure Steam	207.62527
	High Pressure Steam	214.50967
	Refrigerant	0
	Power	415.278
	Cooling Water	21.04
	Air	0
	Low Pressure Steam	200

Table 4.6 Data of target utility usage for multiple utilities


utility i	Current utility usage		Target utility required									
			$\Delta T_{min}=5$		$\Delta T_{min}=10$		$\Delta T_{min}=20$		$\Delta T_{min}=30$		$\Delta T_{min}=40$	
	in kW	in \$	in kW	in \$	in kW	in \$	in kW	in \$	in kW	in \$	in kW	in \$
MP	11190.0	2323326.8										
HP	24638.0	5285089.2	30444.2	6530586	33474.0	7180506.1	39477.5	8468310.5	44499.6	9545598.4	48581.7	10421244.4
RE	306.9	0.0	308.0	0.0	1994.5	0.0	10877.0	0.0	20655.8	0.0	25510.6	0.0
POWER	21222.0	8813029.7	50.9	21138.3	54.9	22786.4	62.8	26082.6	70.7	29378.7	78.7	32672.1
CW	7487.4	157534.4	1300.5	27363.4	1539.4	32389.7	4434.9	93311.2	3895.9	81969.7	4701.2	98913.3
AIR	78638.0	0.0	46103.7	0.0	47217.4	0.0	41429.4	0.0	37237.2	0.0	35759.6	0.0
LP	5944.0	1188800.0										
total		17767780.1		6579087		7235682.2		8587704.2		9656946.8		10552829.8

Step4. Economic Analysis of Investment vs. Savings

The calculated data for energy saving cost and investment cost is in Table 4.7. The investment-saving plot is in Figure 4.4.

Table 4.7 Calculated data for energy saving cost and investment cost

ΔT_{min}	Energy Savings	Extra Area $\Delta\alpha=1$	Extra Area $\Delta\alpha=0.4365$	Savings	ΔN $\Delta\alpha=1$	ΔN $\Delta\alpha=0.4365$	Investment $\Delta\alpha=1$	Investment $\Delta\alpha=0.4365$	payback
C	kW	m ²	m ²	k\$/yr			k\$	k\$	yr
5	26548.4	8497.12	19475.03	11188.693	36	82	1203.752	2741.872	0.245
10	23515.5	6011.09	13777.14	10532.098	26	58	869.383	1939.373	0.184
20	17505.8	3446.92	7900.18	9180.076	15	33	501.568	1103.433	0.120
30	12477.6	2191.64	5023.13	8110.833	10	21	334.385	702.185	0.087
40	8389.3	1419.99	3254.57	7214.950	6	14	200.625	468.128	0.065

**Figure 4.4** Investment-saving plot.**Step5.** Identification of Target ΔT_{min}

Based on the specified payback period (2 years), the required target is the point where the investment is twice the savings. But from the table above at any ΔT_{min} , payback period is less than 2 years. Therefore, the payback period is now chosen to be 0.2 year which correspond to $\Delta T_{min} = 10$ °C.

4.1.5 Design Procedure

The potentials for energy savings in the retrofit project have been identified at the targeting stage. The design procedure will be as in section 3.6. The existing network is analysed where it violates the set targets, by determining the heat exchanger units transferring heat across pinch and having inappropriate utility placement. The grid for existing network (using ΔT_{\min} identified in the targeting stage) was shown in the Figure 4.5 and the heat exchangers crossing the pinch are reported in Table 4.8.

Table 4.8 Heat exchangers, heaters and coolers which transfer heat across the Pinch

HEX	Hot stream	Cold stream	Heat load (kW)
100-E2/2A	H1	C2	4890
110-E1A-D	H8	C9	24174
150-E1A-H	H9	C10	32220
150-E2AB	H12	C11	10300
200-E2	H13	C13	61.5
200-E6A-B	H20	C15	9770
100-E3-3A	C1	HP	16400
100-E11	C4	LP	4
100-E5	C6	LP	5940
110-E2/2A	C7	HP	8238
200-E14	C14	MP	1330
250-EA4	H27	AIR	380
250-EA3	H26	AIR	180
250-EA2	H25	AIR	140
250-E1	C17	MP	9780
250-H3	C21	POWER	211
250-H4	C22	POWER	214
250-E2	C18	MP	80

Then the cross pinch exchangers were eliminated and the network was completed with the new and reused exchangers. However the network compatibility can be improved via heat-load loops and paths. After evolving this improvement to reuse area of existing exchangers as much as possible, the results are shown in Figures 4.6 and 4.7 as alternative design 1 and 2, respectively. The detailed costing for both alternatives is shown below

4.1.5.1 Design Option A

Tables 4.9 and 4.10 show the calculation of investment cost of existing exchangers with new area and new exchangers, respectively. The utility saving calculation is shown in Table 4.11.

Table 4.9 Calculation of investment cost of existing exchangers with extra area for Design option A

HEX	U kW/m ² C	Old Area m ²	New Area m ²	Extra Area m ²	Investment 10 ³ \$
100-E2/2A	0.516	194.11	194.22	0.00	0.000
100-E1	0.473	489.67	665.22	175.54	86.950
100-E6	0.565	29.55	29.55	0.00	0.000
100-E4	0.619	39.92	39.92	0.00	0.000
110-E1A-D	0.303	2238.11	4476.97	2238.86	454.290
150-E1A-H	0.412	1258.17	1853.55	595.38	348.905
150-E2AB	0.607	217.69	217.69	0.00	0.000
200-E2	0.315	1.56	3.13	1.57	35.998
200-E6A-B	0.613	257.50	257.50	0.00	0.000
Total investment					926.143

Table 4.10 Calculation of investment cost for new area of exchangers for Design option A

HEX	Area m ²	Investment 10 ³ \$
N1	127.33	123.868
N2	297.29	213.173
N3	1.34	34.453
N4	2.20	34.963
N5	2.26	34.998
N6	39.14	49.294
N7	288.09	113.377
N8	2.36	35.052
N9	110.24	70.144
N10	0.05	33.495
N11	0.16	33.835
H52	1.87	34.775
H53	102.62	109.366
Total investment		920.792

Therefore the investment for extra area and new area is 1846.935 k\$.

Table 4.11 Calculation of utility savings for Design option A

HEX	Old Q kW	New Q kW	Saved Q kW	Utility Type	annual cost \$/kWyr	Savings 103 \$/yr
100-EA3	4060	4199.80	-139.80	AIR	0.00	0.000
100-EA1	13110	13110.00	0.00	AIR	0.00	0.000
100-EA2	10470	8602.47	1867.53	AIR	0.00	0.000
100-E9	650	650.00	0.00	CW	21.04	0.000
100-E7	230	230.00	0.00	CW	21.04	0.000
100-E10	40	40.00	0.00	RE	0.00	0.000
100-EA4	4310	4310.00	0.00	AIR	0.00	0.000
100-EA5	800	800.00	0.00	AIR	0.00	0.000
100-E12AB	320	320.00	0.00	CW	21.04	0.000
100-E3-3A	16400	14672.27	1727.73	HP	214.51	370.614
100-E11	4	0.00	4.00	LP	200.00	0.800
100-E5	5940	5084.00	856.00	LP	200.00	171.200
110-EA1	2898	0.00	2898.00	AIR	0.00	0.000
110-E2/2A	8238	5247.18	2990.82	HP	214.51	641.559
150-H1	6480	5249.31	1230.69	POWER	415.28	511.078
150-EA3	4150	2320.00	1830.00	AIR	0.00	0.000
150-EA1	8040	8040.00	0.00	AIR	0.00	0.000

Table 4.11 (continued) Calculation of utility savings for Design option A

HEX	Old Q kW	New Q kW	Saved Q kW	Utility Type	annual cost \$/kWyr	Savings 10 ³ \$/yr
150-EA2	3210	3210.00	0.00	AIR	0.00	0.000
150-H2	6600	6600.00	0.00	POWER	415.28	0.000
200-EA1	15070	15070.00	0.00	AIR	0.00	0.000
200-E12	413.077	413.08	0.00	CW	21.04	0.000
200-E13	186.923	186.92	0.00	RE	0.00	0.000
200-EA2	2650	2650.00	0.00	AIR	0.00	0.000
200-E3	1087	1087.00	0.00	CW	21.04	0.000
200-EA3	2320	2320.00	0.00	AIR	0.00	0.000
200-E4AB	1873	1873.00	0.00	CW	21.04	0.000
200-E5	92.3	92.30	0.00	CW	21.04	0.000
200-E7A/B	2670	2670.00	0.00	CW	21.04	0.000
200-E15	79.9438	79.94	0.00	RE	0.00	0.000
200-E14	1330	0.00	1330.00	MP	207.63	276.142
200-H5	7370	7370.00	0.00	POWER	415.28	0.000
250-EA4	380	256.81	123.19	AIR	0.00	0.000
250-EA3	180	180.00	0.00	AIR	0.00	0.000
250-EA2	140	140.00	0.00	AIR	0.00	0.000
250-EA1	250	250.00	0.00	AIR	0.00	0.000
250-E3	152	152.00	0.00	CW	21.04	0.000
250-E1	9780	0.00	9780.00	MP	207.63	2030.575
250-H2	322	322.00	0.00	POWER	415.28	0.000
250-H1	25	25.00	0.00	POWER	415.28	0.000
250-H3	211	27.40	183.60	POWER	415.28	76.244
250-H4	214	131.63	82.37	POWER	415.28	34.206
250-E2	80	0.00	80.00	MP	207.63	16.610
H1	0	94.00	-94.00	LP	200.00	-18.800
H2	0	13423.17	-13423.17	HP	214.51	-2879.401
Total saving						1230.827

The investment cost and saving give 1.5 year payback period with 7.93% energy saving (11.326 MW).

4.1.5.2 Design Option B

Tables 4.12 and 4.13 show the calculation of investment cost of existing exchangers with new area and new exchanger respectively. The utility saving calculation is shown in Table 4.14.

Table 4.12 Calculation of investment cost of existing exchangers with extra area for Design option B

HEX	U kW/m ² °C	Old Area m ²	New Area m ²	Extra Area m ²	Investment 10 ³ \$
100-E2/2A	0.516	194.11	211.52	17.42	41.659
100-E1	0.473	489.67	878.69	389.02	135.399
100-E6	0.565	29.55	29.55	0.00	0.000
100-E4	0.619	39.92	39.92	0.00	0.000
110-E1A-D	0.303	2238.11	4476.97	2238.86	454.290
150-E1A-H	0.412	1258.17	1853.55	595.38	348.905
150-E2AB	0.607	217.69	218.23	0.00	0.000
200-E2	0.315	1.56	3.13	1.57	35.998
200-E6A-B	0.613	257.50	257.50	0.00	0.000
Total investment					1016.252

Table 4.13 Calculation of investment cost for new exchangers for Design option B

HEX	Area m ²	Investment 10 ³ \$
N1	30.01	61.477
N2	14.48	34.586
N3	0.36	34.194
N4	911.78	236.721
N5	0.16	33.835
N6	2.67	37.371
N7	6.37	37.068
N8	0.98	35.171
N9	1.93	36.463
N10	8.34	63.226
N11	0.05	33.495
N12	0.79	34.900
H1	1.87	34.775
H2	7.56	37.613
Total investment		704.544

Therefore the investment for extra area and new area is 1767.144 k\$.




Figure 4.7 Grid diagram of Design option B.

Table 4.14 Calculation of utility savings for Design option B

HEX	Old Q kW	New Q kW	Saved Q kW	Utility Type	annual cost \$/kWyr	Savings 10 ³ \$/yr
100-EA3	4060	6323.33	2263.33	AIR	0.000	0.000
100-EA1	13110	13110.00	0.00	AIR	0.000	0.000
100-EA2	10470	2662.46	7807.54	AIR	0.000	0.000
100-E9	650	650.00	0.00	CW	21.040	0.000
100-E7	230	230.00	0.00	CW	21.040	0.000
100-E10	40	40.00	0.00	RE	0.000	0.000
100-EA4	4310	4310.00	0.00	AIR	0.000	0.000
100-EA5	800	800.00	0.00	AIR	0.000	0.000
100-E12AB	320	320.00	0.00	CW	21.040	0.000
100-E3-3A	16400	15620.28	779.73	HP	214.510	167.259
100-E11	4	0.00	4.00	LP	200.000	0.800
100-E5	5940	0.00	5940.00	LP	200.000	1188.000
110-EA1	2898	0.00	2898.00	AIR	0.000	0.000
110-E2/2A	8238	5246.88	2991.12	HP	214.510	641.624
150-H1	6480	5249.31	1230.69	POWER	415.278	511.078
150-EA3	4150	4125.67	24.33	AIR	0.000	0.000
150-EA1	8040	8040.00	0.00	AIR	0.000	0.000
150-EA2	3210	0.00	3210.00	AIR	0.000	0.000
150-H2	6600	6600.00	0.00	POWER	415.278	0.000
200-EA1	15070	15070.00	0.00	AIR	0.000	0.000
200-E12	413.077	413.08	0.00	CW	21.040	0.000
200-E13	186.923	186.92	0.00	RE	0.000	0.000
200-EA2	2650	2650.00	0.00	AIR	0.000	0.000
200-E3	1087	1087.00	0.00	CW	21.040	0.000
200-EA3	2320	2320.00	0.00	AIR	0.000	0.000
200-E4AB	1873	1873.00	0.00	CW	21.040	0.000
200-E5	92.3	92.30	0.00	CW	21.040	0.000
200-E7A/B	2670	2670.00	0.00	CW	21.040	0.000
200-E15	79.9438	79.94	0.00	RE	0.000	0.000
200-E14	1330	1330.00	0.00	MP	207.625	0.000
200-H5	7370	7113.19	256.81	POWER	415.278	106.649
250-EA4	380	0.00	380.00	AIR	0.000	0.000
250-EA3	180	120.30	59.70	AIR	0.000	0.000
250-EA2	140	77.92	62.08	AIR	0.000	0.000
250-EA1	250	250.00	0.00	AIR	0.000	0.000
250-E3	152	152.00	0.00	CW	21.040	0.000
250-E1	9780	5630.00	4150.00	MP	207.625	861.645

Table 4.14 (continued) Calculation of utility savings for Design option B

HEX	Old Q kW	New Q kW	Saved Q kW	Utility Type	annual cost \$/kW _{yr}	Savings 10 ³ \$/yr
250-H2	322	322.00	0.00	POWER	415.278	0.000
250-H1	25	25.00	0.00	POWER	415.278	0.000
250-H3	211	18.11	192.89	POWER	415.278	80.102
250-H4	214	517.75	-303.75	POWER	415.278	-126.141
250-E2	80	80.00	0.00	MP	207.625	0.000
H1	0	94.00	-94.00	LP	200.000	-18.800
H2	0	1230.69	-1230.6	HP	214.510	-263.994
Total saving						3148.22

The investment cost and saving give 0.561 year payback period (6.7 months) with 18.27% energy savings (26.1 MW).

4.2 Actual Case (as of October 10, 2003)

4.2.1 Process Data

The temperature and flow rate of streams can be measured by the instruments and are concluded in the Table 3.4 of Chapter III. The streams were assumed to have the same composition as in design case which results in the same heat capacity, dew point and bubble point temperature. The value of these data which some streams are adjusted for energy balance of heat exchanger was concluded in Table 4.15. The location and information of each stream are described in Appendix A-2.

Table 4.15 Process data of actual case (hot streams)

STREAM	stream in		stream out		phase change	Tdew C	Tbubble C	flowrate kg/hr	Cp in kWhr/kgC	Cp out kWhr/kgC	Cp avg kWhr/kgC	mCp		Tin C	Tout C	Temp change for sensible heat (C)	total duty MW
	name	phase	name	phase								sensible heat kW/C	latent heat kW/C				
H1	346	liq	351	liq	X	-	-	76160.0	0.000863	0.000611	0.000737	47.663		241.48	57.51	241.478-57.51	8.769
H2	306	mixed	310	liq	✓	-	111.02	215034.6	0.000571	0.000629	0.000600	129.009	627.595	133.45	95.21	111.023-95.209	0.000
H3	540	liq	544	liq	X	-	-	20374.1	0.001169	0.000728	0.000948	18.036		107.84	35.61	107.84-35.61	1.303
H4	606	mixed	604	mixed	✓	-	-	3476.8	0.000687	0.000887	0.000787	2.736	10.593	55.08	36.96	-	0.000
H5	605	mixed	525	mixed	✓	-	-	772.2	0.000675	0.000824	0.000749	0.579	2.667	36.96	19.20	-	0.000
H6	511	liq	565	liq	X	-	-	28480.2	0.000786	0.000629	0.000707	20.106		110.17	31.05	110.168-31.047	1.591
H7	499	vapor	498	mixed	✓	53.93	-	47001.3	0.000562	0.000793	0.000678	31.843	613.075	55.14	45.85	55.136-53.925	0.000
H8	006		008		X	-	-	123979.9	0.000840	0.000608	0.000724	76.427		190.88	60.00	190.876-60.002	10.002
H9	131	vapor	132	mixed	✓	276.67	-	131970.9	0.000806	0.000682	0.000744	56.459	170.954	322.97	132.82	322.972-276.672	0.000
H10	136	mixed	137	mixed	✓	-	-	139105.0	0.000668	0.000585	0.000627	87.171	111.667	132.82	51.01	-	0.000
H11	307	vapor	309	mixed	✓	51.45	-	27959.7	0.000934	0.000829	0.000882	24.650	791.088	153.50	49.64	162.51-44.9	0.000
H12	341	liq	399	liq	X	-	-	129864.4	0.000838	0.000638	0.000738	100.884		206.70	63.14	206.704-63.137	14.484
H13	194	vapor	195	vapor	X	-	-	187.3	0.000969	0.000722	0.000845	0.087		510.93	62.13	510.925-62.133	0.039
H14	167	mixed	181	mixed	✓	-	-	139684.4	0.000690	0.000902	0.000796	111.138	275.654	95.03	46.02	-	0.000
H15	1204	vapor	1212	mixed	✓	61.71	-	20308.3	0.001340	0.001284	0.001312	26.638	30.571	130.28	54.49	130.28-61.71	0.000
H16	1122	vapor	1123	mixed	✓	63.57	-	3219.2	0.001052	0.001276	0.001164	3.747	6.676	112.83	9.71	112.826-63.567	0.000
H17	1164	mixed	1165	mixed	✓	-	-	137669.0	0.000945	0.000976	0.000961	132.281	121.453	43.71	36.71	-	0.000
H18	1214	mixed	1215	mixed	✓	-	-	123456.5	0.001180	0.001262	0.001221	150.781	101.738	54.72	36.72	-	0.000
H19	1254	vapor	1265	mixed	✓	44.58	-	2258.8	0.001680	0.001672	0.001676	3.786	4.286	67.30	32.53	67.305-44.854	0.000
H20	1474	liq	1469	liq	X	-	-	152420.0	0.000747	0.000593	0.000670	97.053		207.29	118.90	207.288-118.902	8.578
H21	1406	mixed	1409	mixed	✓	-	-	24948.4	0.000582	0.000750	0.000666	16.616	98.212	63.38	39.78	63.378-39.78	0.000
H22	1411	vapor		mixed	✓	37.32	-	1270.0	0.000563	0.000650	0.000606	0.770	2.719	38.54	19.48	38.545-37.323	0.000
H28	1154	vapor	1162	mixed	✓	69.39	-	26543.9	0.000123	0.001107	0.000615	16.320	115.108	138.81	57.70	138.81-69.391	0.000
H29	170	mixed	173	liq	✓	-	68.66	115108.0	0.000575	0.000700	0.000638	73.413	454.858	80.53	51.69	68.662-51.69313	0.000

Table 4.15 (Continued) Process data of actual case (Cold streams)

STREAM	stream in		stream out		phase change	Tdew C	Tbubble C	flowrate kg/hr	Cp in kWhr/kgC	Cp out kWhr/kgC	Cp avg kWhr/kgC	mCp		Tin C	Tout C	Temp change for sensible heat (C)	total duty MW
	name	phase	name	phase								sensible heat kW/C	latent heat kW/C				
C1	131	liq	138	mixed	✓	-	192.32	151146.2	0.000769	0.000743	0.000756	114.242	1829.517	184.95	198.95	184.949-192.322	0.000
C2	103	liq	110	liq	✗	-	-	252330.0	0.000573	0.000725	0.000649	159.692		29.34	108.18	29.343-131.399	0.000
					✗	-	-	252330.0	0.000573	0.000725	0.000649	199.197		108.18	131.40		
C3	517	liq	513	liq	✗	-	-	18040.7	0.000741	0.000864	0.000803	15.594		42.97	71.78	42.974-71.778	0.449
C4	525	vapor	527	vapor	✗	-	-	510.0	0.000665	0.000523	0.000594	0.303		19.20	75.17	19.197-75.175	0.017
C5	302	liq	305	liq	✗	-	-	43760.0	0.000700	0.000750	0.000725	31.800		52.12	71.14	52.125-71.143	0.605
C6	507	liq	508	liq	✗	-	116.01	183161.4	0.000791	0.000736	0.000763	139.828	2755.387	110.17	113.17	110.168-113.168	0.419
C7					✗	-	-	123979.9	0.000764	0.000838	0.000801	99.304		157.29	192.00	157.289-192.001	3.447
C8					✗	-	-	129525.8	0.000764	0.000838	0.000801	103.747		60.00	81.76	60.002-81.757	2.257
C9			002		✗	-	-	129514.3	0.000549	0.000765	0.000657	103.050		97.89	157.29	36.8-188.7	6.121
C10	112	liq	115	vapor	✓	288.98	263.48	139105.8	0.000579	0.000821	0.000700	108.023	499.122	81.87	324.81	81.865-263.482,288.	0.000
C11	151	mixed	306	mixed	✓	-	-	130147.9	0.000567	0.000717	0.000642	83.577	90.837	51.28	160.70	-	0.000
C12	334	liq	338	liq	✗	-	222.00	264064.0	0.000838	0.000730	0.000784	207.027	825.000	206.70	213.16	220-230	0.000
C13	190	vapor	193	vapor	✗	-	-	94.5	0.001051	0.001228	0.001139	0.607		112.83	177.00	111.8-315.6	0.039
C14	1720	liq	1405-1420	liq	✗	-	-	40519.5	0.000671	0.000797	0.000734	29.750		35.00	127.32	86-162	2.747
C15	1438	liq	1420	liq	✗	-	-	116891.3	0.000502	0.000652	0.000577	71.154		36.98	157.54	37-154.1	8.578
C16	1449	liq	1451	mixed	✓	-	213.72	149998.6	0.000747	0.000659	0.000703	105.487	501.580	207.29	230.55	211.7-213.715	0.000

4.2.2 Energy Target

The problem table analysis and grand composite curves at any minimum approach temperatures had been done as in the procedure in section 3.4. The data extracted from grand composite curve will give the minimum utility requirement which results in minimum total cost and minimum heat exchanger capital investment cost at any ΔT_{\min} . The problem table algorithm (PTA) for any ΔT_{\min} can be done as in actual case and the result of PTA is shown in Table 4.16.

Table 4.16 Result of PTA at various ΔT_{\min}

ΔT_{\min} C	$Q_{H\min}$ MW	$Q_{C\min}$ MW	pinch C
5	30.507	51.976	194.822
10	28.825	54.959	197.322
20	32.325	57.660	196.704
30	34.750	60.984	199.949
40	36.937	62.271	204.949
51.034	41.322	66.656	123.409

The actual case of existing plant uses 66.656 MW of hot utility and 41.322 MW cold utility of cold utility in the process. The reduced utility is from removing some exchangers that can not be modified. These values of both utilities tell that ΔT_{\min} of the process is 51.034 °C. The ΔT_{\min} of this process, comparing with the similar process in many literatures which is about 10-20 °C (Linnhoff, 1998), is very high. This can be concluded that the utility usage in the process is too high and can be reduced by recovering process to process energy.

4.2.3 Area Target

The surface area of over all and each of existing heat exchanger is shown in Table 4.17. The hot and cold composite curves for calculating minimum area at any ΔT_{\min} are shown in Figure 4.8. The procedure to construct the curves as in section 3.5 is shown in Appendix C-2. The result from this analysis is in Table 4.18.

Table 4.17 Surface area of existing heat exchangers in the process

HEX	Stream	surface area m ²
100-E1	H2	661
	C2	
100-E2/2A	H1	202.700
	C2	
100-E4	H6	76.700
	C5	
100-E6	H3	32.700
	C3	
110-E1A-D	H8	2768.000
	C9	
150-E1A-II	H9	1944.000
	C10	
150-E2AB	H12	231.600
	C11	
200-E2	H13	6.977
	C13	
200-E6A/B	H20	265.400
	C15	
total area		6189.077 m ²

Table 4.18 Result from area targeting at various ΔT_{\min}

ΔT_{\min} C	A_{ideal} m ²
5	7093.461
10	5429.980
20	3983.7413
30	3378.9582
40	2959.0727
51.034 (existing case)	2357.4488




Figure 4.8 Hot and Cold composite curves at various ΔT_{min} .

4.2.4 Setting Retrofit Targets

Step1. Calculation of Area Targets for Various Energy Levels and Area Efficiency of Existing network

The existing HEN has an area efficiency of 0.380905, where the existing area (A_{existing}) and target area (A_{ideal}) for the existing energy recovery are 6187.01 and 2357.45 m^2 , respectively.

Step 2. Calculation of the Retrofit Curve

The utility demands and area requirement for each global ΔT_{min} which were calculated in sections 4.2.2 and 4.2.3 are concluded in Table 4.19 and the area-energy plot is in Figure 4.9.

Table 4.19 Area-Energy data for various ΔT_{min}

ΔT_{min} C	$Q_{\text{cu,min}}$ kW	$Q_{\text{hu,min}}$ kW	A_{ideal} m^2	$A_{\text{max,retr}}$ $\Delta\alpha=1$	$A_{\text{max,retr}}$ $\Delta\alpha=0.4365$
5	51975.8	26641.5	7093.46	10925.09	18622.66
10	54059.1	28724.8	5429.98	9261.61	14255.48
20	57659.5	32325.2	3983.74	7815.37	10458.63
30	60083.8	34749.5	3378.96	7210.59	8870.87
40	62270.8	36936.5	2959.07	6790.70	7768.54
51.034	66656.0	41321.7	2357.45	6189.08	6189.08




Figure 4.9 Retrofit Curve on Area-Energy Plot.

Step3. Calculation of Energy Saving and Extra Area Required

Before calculation of the energy saving, the utility usage for multiple utility levels is required and doing Problem Table Analysis will be very useful in this step as shown in Appendix D-2. The data of target utility usage for various ΔT_{\min} was concluded in the Table 4.20 where

Annual cost of utilities in \$(/kWyr) for :	Medium Pressure steam	207.62527
	High Pressure steam	214.50967
	Refrigerant	0
	Power	415.278
	Cooling Water	21.04
	Air	0
	Low Pressure steam	200

Table 4.20 Data of target utility usage for multiple utilities


utility i	Current utility usage		Target utility required									
			$\Delta T_{\min}=5$		$\Delta T_{\min}=10$		$\Delta T_{\min}=20$		$\Delta T_{\min}=30$		$\Delta T_{\min}=40$	
	in kW	in \$	in kW	in \$	in kW	in \$	in kW	in \$	in kW	in \$	in kW	in \$
MP	2747	570266										
HP	5704	1223587	25919	5559919	27462	5890929	29983	6431558	31327	6719859	33082	7096495
RE	243	0	6381	0	31048	0	17538	0	20548	0	43833	0
POWER	19468	8084794										
CW	6776	142577	20042	421691	17511	368434	17150	360841	20984	441504	4165	87638
AIR	59637	0	25552	0	5500	0	22971	0	18552	0	14272	0
LP	436	87286										
total		10108509		5981610		6259363		6792399		7161363		7184133

Step4. Economic Analysis of Investment vs. Savings

The calculated data for energy saving cost and investment cost is in Table 4.21. The investment-saving plot is in Figure 4.10.

Table 4.21 Calculated data for energy saving cost and investment cost

ΔT_{min}	Energy Savings	Extra Area $\Delta\alpha=1$	Extra Area $\Delta\alpha=0.4365$	Savings	ΔN $\Delta\alpha=1$	ΔN $\Delta\alpha=0.4365$	Investment $\Delta\alpha=1$	Investment $\Delta\alpha=0.4365$	payback
C	kW	m ²	m ²	k\$/yr			k\$	k\$	yr
5	14680.2	10925.09	18622.66	4126.899	46	78	1538.123	2608.117	0.632
10	12596.9	9261.61	14255.48	3849.146	39	60	1304.061	2006.248	0.521
20	8996.5	7815.37	10458.63	3316.110	33	44	1103.437	1471.248	0.444
30	6572.2	7210.59	8870.87	2947.146	30	37	1003.119	1237.182	0.420
40	4385.2	6790.70	7768.54	2924.376	29	33	969.692	1103.440	0.377

**Figure 4.10** Investment-Saving plot.**Step5.** Identification of Target ΔT_{min}

Based on the specified payback period (2 years), the required target is the point where the investment is twice the savings. But from the table above at any ΔT_{min} , payback period is less than 2 years. Therefore, the payback period is now chosen to be 0.5 year which corresponds to ΔT_{min} 12.736 °C.

4.2.5 Design Procedure

As in design case the network is analysed to determine the heat exchanger units that transfer heat across pinch and inappropriate utility placement. The grid for existing network (using ΔT_{\min} identified in the targeting stage) was shown in the Figure 4.11 and the heat exchangers crossing the pinch are reported in Table 4.22.

Table 4.22 Heat exchangers, heater and cooler which transfer heat across the Pinch

HEX no.	HEX name	Hot stream	Cold stream	Heat load (kW)
2	100-E2/2A	1	2	4624.400
3	100-E3/3A	HP	1	12966.200
5	100-E5	LP	6	419.485
10	100-E11	LP	4	16.945
18	110-E2	HP	8	2257.050
19	110-E2A	HP	7	3447.060
21	150-E1A-H	9	10	27205.900
22	150-E2AB	12	11	9939.380
28	200-E2	13	13	38.979
32	200-E6AB	20	15	8578.160
36	200-E14	MP	14	2746.610




Figure 4.11 Grid diagram of existing plant with pinch temperature.

A summary of the heat flow violation of the pinch is given in Table 4.23. The process-to-process heat exchangers transfer significant amounts of heat, especially HEX 2. Also hot utility units HEX 18, 19 and 36 also transfer considerable amounts. But no cold utility unit transfers heat across pinch.

Table 4.23 Summary of pinch design violation of existing network

HEX no.	HEX name	Heat flow across pinch (kW)	cold utility above pinch (kW)	Hot utility below pinch (kW)
2	100-E2/2A	1735.874		
3	100-E3/3A			842.325
5	100-E5			419.485
10	100-E11			16.945
18	110-E2			2257.050
19	110-E2A			3447.060
21	150-E1A-H	417.386		
22	150-E2AB	166.045		
28	200-E2	26.580		
32	200-E6AB	216.419		
36	200-E14			2746.610

At the targeting stage, the potential for energy savings is set by the economics of the process. The optimum energy recovery corresponds to a minimum approach temperature of 12.736°C, and the minimum energy consumption of the process is given by the composite curves.

Unlike the design case retrofit which the cross pinch exchangers were eliminated and the network was completed with the new and reused exchanger, only exchangers that transfer the significant amount of heat will be considered.

In the diagnosis stage, inspection for topology changes, which increases energy savings by shifting heat from below to above the network pinch, are carried out. The modifications considered include resequencing, repiping and the addition of new heat exchangers. Split heuristics modifications are implemented whenever the network pinch and process pinch coincides. With these modification methods the across pinch exchanger will be eliminated and the heat flow across pinch will be reduced.

4.2.5.1 Diagnosis Stage

The purpose of this stage is to identify design options that overcome the network pinch and increases the energy recovery of the network. The inspection for potential topology changes is sequential. At each step resequencing is considered first, followed by repiping, and finally by adding of a new heat exchanger. As the area efficiency method was used for targeting, the optimum value of the minimum approach temperature obtained from it, 12.736°C was used for the retrofit design in this study. The design objective in the diagnosis stage was set for minimum energy consumption. A summary of the steps taken in the diagnosis stage for the different design options is shown in Figure 4.12.

Design Option A

- 1) There is no beneficial resequencing modifications, repiping was considered. The inspection gives two beneficial options: repiping of HEX 2's cold stream to C1 and repiping of HEX 2's cold stream to C12. The first option with more energy savings was chosen while the second option will be used in design option D since more utility saving cost was obtained. This gives MP steam duty savings of HEX 3 about 1.458 MW.
- 2) The next modifications for this design option is the addition of new heat exchanger. Since repiping of HEX 2, the stream C2 now need heating with the hot stream having high enough temperature and this results in addition of HEX 42 between H12 and C2.
- 3) The modification continues with the addition of new heat exchanger HEX 43. The best few options identified are H1-C8, H1-C14 and H10-C8. The first two options will save the MP steam duty while the third option will save the HP steam duty. But the third option is not considered as it will be explored in design option B. Then the match between H1-C14 with more energy savings is selected which gives 2.746 MW energy savings




Figure 4.12 The design solution search tree for diagnosis stage of HEN.

4) No beneficial modifications are found for repiping and resequencing. The addition of new heat exchanger HEX 44 between H1-C8 gives the best energy recovery.

At this stage the inspection is stopped. There are a number of modifications made and now there is no match that gives significant energy savings.

Design Option B

1) As mentioned above in design option A the first two modifications are the same as design option A. The third modification is the addition of HEX 43 between H10-C8 that gives 2.257 MW of energy savings.

2) Since stream H1 has high temperature enough to exchange heat with cold stream C7, the addition of HEX 44 between H1-C7 is selected and 1.947 MW of HP steam duty could be saved.

3) Further modification is addition of HEX 45 between H1-C14, which give the best energy recovery.

Design Option C

1) This search begins with the addition of new heat exchangers. The first modification should reduce heat transferring across pinch of HEX 2. Therefore the match of HEX 42 between H1-C1 is selected. But this action will change the duty and area of HEX 1 and HEX 2. To minimize the investment cost of added area of these two heat exchangers, the same area of HEX 2 is used, resulting in 4.366 MW of energy savings.

2) The next modification is the addition of HEX 43 which gives two options with maximum energy recovery of stream C8. The two matches are H1-C8 and H10-C8. The match of H10-C8 is selected as in this case since there is large driving force or else low new area with 4.514 MW.

3) The addition of new heat exchanger HEX 44 also gives two options. The first option with the maximum energy recovery is the match between H11 and C14. Although the second option, the match between H28 and C14, saves less energy, the stream match is in the same unit (unit 200) which gives less piping costs. In this design the first option is selected because of the higher utility cost savings. This option gives 5.493 MW of energy savings.

Design Option D

1) As mentioned in design option A, the first modification is repiping HEX 2's cold stream to C12 with the heating duty saving of 1.050 MW.

2) The next modification is the addition of new heat exchanger HEX 42 between H1 and C7 since the hot stream, H1, has high temperature enough to exchange heat with cold stream C7. This modification saves HP steam duty of 2.355 MW.

3) The next modification is the addition of new heat exchanger HEX 43 between H1-C8 with the maximum energy recovery of cold stream C8, which saves energy about 2.257 MW.

4) The further modification is the addition of new heat exchanger HEX 44 between H11-C14 with the maximum energy recovery of cold stream C14. This modification gives 5.493 MW of energy savings.

5) The last modification for this design option is the addition of new heat exchanger. Due to the repiping of HEX 2, the stream C2 is heated with the hot stream that has high temperature. And as in design option A the addition of HEX 42 between H12 and C2 is selected.

4.2.5.2 Optimized Design Options Results

After all the modifications of each design option have been completed, grid diagrams of the modified network of design options A, B, C and D are generated, and shown in Figures 4.13, 4.14, 4.15 and 4.16, respectively. The retrofit network cost report of all design options are in Appendix E. A summary of the design options modifications are :

Design Option A

- 12.95 MW of energy savings correspond to a utility cost saving about 1.367 M US\$ and investment cost of 0.48946 M US\$ gives a payback period of 0.358 year.
- Two hot utility units using MP steam and HP steam are removed. The duty of other hot utility unit using HP steam is reduced.

Design Option B

- 16.691 MW of energy savings corresponding to a utility cost saving about 1.752 M US\$ and investment cost of 0.6304 M US\$ giving a payback period of 0.36 year.
- Two hot utility units using MP steam and HP steam are removed. The duty of other hot utility units using HP steam are reduced.




Figure 4.13 Grid diagram for actual case of design option A.




Figure 4.14 Grid diagram for actual case of design option B.




Figure 4.15 Grid diagram for actual case of design option C.




Figure 4.16 Grid diagram for actual case of design option D.

Design Option C

- 12.92 MW of energy savings correspond to a utility cost saving about 1.3672 M US\$ and investment cost of 0.3632 M US\$ gives a payback period of 0.266 year.
- Two hot utility units using MP steam and HP steam are removed. The duty of other hot utility unit using HP steam is reduced.

Design Option D

- 16.846 MW of energy savings correspond to a utility cost saving about 1.996 M US\$ and investment cost of 0.6791 M US\$ gives a payback period of 0.340 year.
- Two hot utility units using MP steam and HP steam are removed. The duty of other hot utility unit using HP steam is reduced.

For all the design options, the utility units are reduced to zero load. Two design options had three new heat exchangers added to them but other two design options had four new heat exchangers. The number of extra units was limited to keep investment costs low. A number of modifications identified for the different design options are similar. There were two repiping options identified, which is repiping of HEX 2 which transfers a large amount of heat across the pinch. The repiping of HEX 2 moves heat from below to above the pinch and reduced the utility cost significantly since it also reduced the amount of MP steam or power. The rest of the modifications are the addition of new exchangers. The new exchangers include matches between hot streams and cold streams that violate the pinch. The impact on the cost depends on type of hot utility mediums.

The energy savings achieved at each modification step in the diagnosis stage are shown in Figure 4.17. Design D seems to give a good energy saving overall. The comparison of the results of the design options together with the existing design is given in Table 4.24. They all give payback period under 0.5 year.




Figure 4.17 Comparison of energy savings for the different design options.

Table 4.24 Comparison of design option parameter with existing design

Design	Utility cost (M\$/y)	Area (m ²)	ΔA (m ²)	no. of units	Payback (y)
Existing	10.109	6189.08		41	
Option A	8.741	7139.18	950.105	44	0.36
Option B	8.357	7365.11	1176.03	45	0.36
Option C	8.741	6779.35	590.265	44	0.27
Option D	8.113	7533.41	1344.33	45	0.34