


## CHAPTER IV RESULTS AND DISCUSSION


### 4.1 Retrofit Case Study

#### 4.1.1 Introduction

This problem considers the retrofit of a heat exchanger network of a crude distillation unit with pre-flash drum, as shown in Figure 4.1. with 11 streams and 9 exchangers, the base case of CDU is operated under TROLL (light crude), FOROZAN (medium crude) and SOUEDIE (heavy crude), (<http://www.bp.com>) with different distillation curves (Figure 4.2). The properties of the light crude, medium crude and heavy crude are shown in Tables 4.2-4.5. Crude is preheated to a temperature of 125 °C, for desalting purposes. After that crude is preheated to 170 °C in order to preflash before is heated to 370 °C and then enter to the distillation column. In this example, 5 - 95 gaps and ASTM D86 (95 % point) of product are used as separation criteria. The term gap refers to the difference between the 5% ASTM D86 distillation temperature of a heavier product and the 95 % ASTM D86 distillation temperature of an adjacent lighter product. When the distillation curves of the two products overlap, a negative gap appears. Table 4.6 indicates the specifications of the products and the product withdraw locations. The column data are shown in Table 4.7. Table 4.8 shows the set of design variables.



**Figure 4.1** The crude distillation unit with pre-flash drum.



**Figure 4.2** Distillation curves of multiple crude.

**Table 4.1** Crude used for study case

Crude	API	Throughput (m <sup>3</sup> /hr)
Light crude	35.87	795
Medium crude	30.19	795
Heavy crude	23.12	795

**Table 4.2** TBP data of Light crude

Vol %	Temperature (°C)
2.2	15
5.6	65
11.9	100
22.8	150
32.3	200
41.8	250
53.2	300
63.5	350
67.2	370
80.2	450
86.5	500
91.0	550

**Table 4.3** TBP data of Medium crude

Vol %	Temperature (°C)
1.3	15
6.3	75
18.0	145
33.0	230
56.8	375
80.6	560
81.2	565

**Table 4.4** TBP data of Heavy crude

Vol %	Temperature (°C)	Vol %	Temperature (°C)
13.9	140	43.9	350
15.3	150	45.4	360
16.7	160	46.9	370
19.4	180	48.3	380
22.0	200	49.8	390
24.7	220	51.2	400
27.5	240	58.3	450
29.0	250	61.7	475
30.4	260	65.1	500
36.3	300	68.4	525
37.8	310	71.7	550
39.4	320	73.7	565
40.9	330		

**Table 4.5** Light-end composition of crude

Compound	Vol %		
	Light crude	Medium crude	Heavy crude
Ethane	0.22	0.01	0
Propane	0.58	0.28	0.07
i-Butane	0.39	0.26	0.13
n-Butane	1.04	0.97	0.63

**Table 4.6** Specifications of the products

<b>Product</b>	<b>Specification</b>	<b>Withdrawal tray</b>
Naphtha	D86 (95 % point) = 182 °C	1
Kerosene	D86 (95 % point) = 271 °C	9
Diesel	D86 (95 % point) = 327 °C	17
AGO	D86 (95 % point) = 410 °C	28
Overflash rate	0.01	
Kerosene-Naphtha	(5-95) Gap = 17.2 °C	
Diesel-Kerosene	(5-95) Gap = 0.6 °C	
AGO-Diesel	(5-95) Gap = -3.4 °C	
Feed tray		29
Total trays		34

**Table 4.7** Column data

<b>Number of Plates</b>	34
<b>Number of trays (Side Strippers)</b>	4
<b>Pump-around 1 (PA1) Draw</b>	Tray 4
<b>Pump-around 1 (PA1) Return</b>	Tray 2
<b>Pump-around 2 (PA2) Draw</b>	Tray 12
<b>Pump-around 2 (PA2) Return</b>	Tray 10
<b>Pump-around 3 (PA3) Draw</b>	Tray 21
<b>Pump-around 3 (PA3) Return</b>	Tray 19
<b>Kerosene Side-Stripper Return</b>	Tray 8
<b>Diesel Side-Stripper Return</b>	Tray 16
<b>AGO Side-Stripper Return</b>	Tray 26
<b>Crude Feed</b>	Tray 29

**Table 4.8** Design variables

Variable	Value		
	Light crude	Medium crude	Heavy crude
<b>Kerosene Stripper Steam @ 260 °C, 4.4 atm (kg/hr)</b>	522.5	832.5	818.6
<b>Diesel Stripper Steam @ 260 °C, 4.4 atm (kg/hr)</b>	2616.5	2080.6	2217.5
<b>AGO Stripper Steam @ 260 °C, 4.4 atm (kg/hr)</b>	2843.0	1860.0	1696.0
<b>Main Steam @ 260 °C, 4.4 atm (kg/hr)</b>	3493		
<b>Overflash</b>	1 %		
<b>Condensor Temperature</b>	32.22 °C		
<b>Pump-around 1 (PA1) Return Temperature</b>	104.44 °C		
<b>Pump-around 2 (PA2) Return Temperature</b>	148.89 °C		
<b>Pump-around 3 (PA3) Return Temperature</b>	232.22 °C		
<b>Pump-around 1 (PA1) Heat Rate</b>	11.7 MW		
<b>Pump-around 2 (PA2) Heat Rate</b>	8.8 MW		
<b>Pump-around 3 (PA3) Heat Rate</b>	8.8 MW		

The existing exchanger network configuration is shown in Figure 4.3. The existing network does not have splitters. The stream properties are shown in Table 4.9, 4.10 and 4.11, the existing heat exchangers areas and heat load are shown in Table 4.12. The original HEN consumes 315539 MW/hr of hot utility and 149255 MW/hr of cold utility. The results will be compared for a project life of 5 years, 10 % interest rate and presented in the discussion section. 350 working days per year is assumed. The costs of hot and cold utilities are 0.4431 and 0.0222 cent/MJ, respectively.


The maximum values of area addition and reduction that can be made to existing shells are 20 % and 50 % of the corresponding existing area; respectively. The maximum area per shell is 5,000 (m<sup>2</sup>), the maximum number of shells per exchanger is 4. The model was run for maximizing the net present value (NPV). The cost relations for area adjustment are shown Equation 4.1, 4.2, 4.3 and 4.4. Costs are assigned to splitting of 20,000 \$ and to relocation of 25,000 \$.

$$\text{Exchanger (\$)} = 8,600 + [670 \times \text{Area}^{0.83} (\text{m}^2)] \quad (4.1)$$

$$\text{Area addition (\$)} = 4,300 + [1476 \times \text{Added Area}^{0.83} (\text{m}^2)] \quad (4.2)$$

$$\text{Area reduction (\$)} = 4,300 + [9 \times \text{Reduced Area}^{0.83} (\text{m}^2)] \quad (4.3)$$

$$\text{New shell (\$)} = 8,600 + [1476 \times \text{Area of shell}^{0.83} (\text{m}^2)] \quad (4.4)$$



**Figure 4.3** Existing heat exchanger network.

**Table 4.9** Stream properties of Light crude

Stream	FCp (kW/°C)	T <sub>in</sub> (°C)	T <sub>out</sub> (°C)	h (kW/m <sup>2</sup> °C)	H (kW)
<b>I1</b>	121.02	201.17	104.44	1.293	11707
<b>I2</b>	69.91	274.71	148.89	1.318	8796
<b>I3</b>	98.60	321.17	232.22	1.298	8771
<b>I4</b>	105.22	32.22	30	1.058	234
<b>I5</b>	67.76	234.40	30	1.395	13850
<b>I6</b>	49.64	273.17	30	1.423	12072
<b>I7</b>	59.98	326.40	30	1.343	17779
<b>I8</b>	135.33	341.73	30	0.892	42186
<b>J1</b>	380.57	25	125	0.654	38057
<b>J2</b>	434.32	125	170	0.632	19544
<b>J3</b>	585.63	166.64	370	0.788	119092

**Table 4.10** Stream properties of Medium crude

Stream	FCp (kW/°C)	T <sub>in</sub> (°C)	T <sub>out</sub> (°C)	h (kW/m <sup>2</sup> °C)	H (kW)
I1	125.28	198.28	104.44	1.092	11756
I2	71.80	271.63	148.89	1.235	8812
I3	101.36	319.12	232.22	1.270	8808
I4	92.01	32.22	30	1.253	204
I5	56.28	225.57	30	1.394	11007
I6	34.77	269.78	30	1.431	8338
I7	41.91	326.26	30	1.413	12415
I8	210.12	357.39	30	0.888	68791
J1	387.57	25	125	0.652	38757
J2	443.70	125	170	0.630	19967
J3	587.80	168.84	370	0.782	118241

**Table 4.11** Stream properties of Heavy crude

Stream	FCp (kW/°C)	T <sub>in</sub> (°C)	T <sub>out</sub> (°C)	h (kW/m <sup>2</sup> °C)	H (kW)
I1	132.07	193.31	104.44	1.075	11737
I2	74.03	267.77	148.89	1.221	8801
I3	104.43	316.69	232.22	1.270	8821
I4	70.64	32.22	30	1.309	157
I5	46.81	221.36	30	1.393	8957
I6	29.33	263.57	30	1.438	6851
I7	32.46	322.00	30	1.419	9478
I8	268.65	353.52	30	0.826	86914
J1	392.24	25	125	0.651	39224
J2	449.76	125	170	0.630	20239
J3	555.77	167.81	370	0.780	112370

**Table 4.12** The existing heat exchangers areas and heat load

Exchanger	Area (m <sup>2</sup> )	Heat Load (kW)		
		Light crude	Medium crude	Heavy crude
E1	1218	18866	29963	33546
E2	1035	9229	6574	5021
E3	75	4231	4223	4240
E4	435	5737	3894	3125
E5	485	6094	4354	3291
E6	484	8827	11906	13948
E7	461	6914	10888	13639
E8	142	8796	8697	8644
E9	182	9616	9151	8962


#### 4.1.2 Discussion

In this section the results for each retrofitted designs are compared to find the optimum retrofitted design which gives the maximum NPV. Each retrofitted design was performed using the specified constraints and cost functions. The relocation concept was used to manipulate the area of existing exchangers as well as adding new exchangers and introducing split streams.


##### 4.4.2.1 Retrofit Potential and Design Results

From process pinch analysis by the retrofit potential program the maximum NPV of retrofitted Light crude, Medium crude and Heavy crude design occur at  $\Delta T_{\min}$  of 34.65 °C, 29.80 °C and 55.0 °C respectively. The composite curves of the optimum retrofitted Light crude, Medium crude and Heavy crude are shown in Figure 4.4, 4.6 and 4.8 respectively. The NPV diagrams of the optimum retrofitted Light crude, Medium crude and Heavy crude are shown in Figure 4.5, 4.7 and 4.9 respectively.







**Figure 4.4** Composite curves of the optimum retrofitted Light crude.




**Figure 4.5** NPV diagrams of the optimum retrofitted Light crude.




**Figure 4.6** Composite curves of the optimum retrofitted Medium crude.



**Figure 4.7** NPV diagrams of the optimum retrofitted Medium crude.



**Figure 4.8** Composite curves of the optimum retrofitted Heavy crude




**Figure 4.9** NPV diagrams of the optimum retrofitted Heavy crude.

Now that the optimum  $\Delta T_{\min}$  value has been defined, Table 4.13 shows the optimum  $\Delta T_{\min}$  and the pinch temperature of each retrofit case. The next step is to generate the stream matches for heat exchange in the new network. To do this, a grid diagram of the process is analyzed with the pinch temperature represented as two vertical lines at the middle of the grid. The grid diagram for the

retrofitted network of HEN of Light crude, Medium crude and Heavy crude are illustrated in Figure 4.10, 4.11 and 4.12.

**Table 4.13** The optimum  $\Delta T_{\min}$  and the pinch temperature of each retrofit case

	Light Crude	Medium Crude	Heavy Crude
Optimum $\Delta T_{\min}$ (°C)	34.65	29.80	55.00
Pinch temperature of hot stream(°C)	198.28	201.17	221.36
Pinch temperature of cold stream(°C)	168.48	166.53	166.36



**Figure 4.10** Grid diagram for the retrofitted network of HEN of Light crude.




Figure 4.11 Grid diagram for the retrofitted network of HEN of Medium crude.




Figure 4.12 Grid diagram for the retrofitted network of HEN of Heavy crude.

The first step to design the new network is to locate the existing exchangers that transfer heat across the pinch. Because pinch technology does not allow cross-pinch heat transfer, these exchangers must be eliminated and essentially reused. It can be done by moving each exchanger to one side of the pinch and then altering the input and target temperatures to ensure that no cross-pinch heat

transfer occurs in the new design. As a reminder, the sections above and below the pinch must be analyzed separately.

Then the stream matches are generated by using a mixed integer linear programming (MILP) model using GAMS called the stage model, from Yee and Grossmann (1990). The objective function is to minimize the number of exchanger under constraint functions of energy balance, thermodynamics and logical constraint. At the pinch, use value of EMAT equal to  $\Delta T_{\min}$  from pinch analysis. As matches move away from the pinch, use value of EMAT equal to 5 °C. The retrofitted design of Light crude base, Medium crude base and Heavy crude base are shown in Figure 4.13, 4.14 and 4.15, respectively.




Figure 4.13 Retrofitted design of Light crude base.




Figure 4.14 Retrofitted design of Medium crude base.




Figure 4.15 Retrofitted design of Heavy crude base.

#### 4.4.2.2 Simulation Retrofit Design Results

Then PROII is simulated to perform the utility consumption of multiple crudes (Table 4.17) with the HEN retrofit design from previous step. The duties and the overall heat transfer coefficient of each exchanger are defined. Then PROII will calculate area of each exchanger. Furthermore PROII is also used to validate the retrofit design. Table 4.14, 4.15 and 4.16 show the area of each exchanger from PROII simulation

**Table 4.14** Exchangers areas of Light crude from PROII simulation

Exchanger	Area (m <sup>2</sup> )	Exchanger	Area (m <sup>2</sup> )
ER1	1169.35	ER12	333.36
ER2	465.76	ER13	186.04
ER3	208.13	ER14	138.16
ER4	166.18	ER15	113.19
ER5	137.73	ER16	281.61
ER6	160.22	ER17	139.54
ER7	24.79	ER18	867.83
ER8	16.53	ER19	855.32
ER9	12.24	ER20	623.12
ER10	13.99	ER21	832.65
ER11	15.51		

**Table 4.15** Exchangers areas of Medium crude from PROII simulation

Exchanger	Area (m <sup>2</sup> )	Exchanger	Area (m <sup>2</sup> )
ER1	348.64	ER11	398.58
ER2	1773.35	ER12	130.83
ER3	149.86	ER13	144.67
ER4	13.80	ER14	442.82
ER5	254.70	ER15	111.95
ER6	29.60	ER16	165.43
ER7	132.65	ER17	451.50
ER8	89.01	ER18	804.57
ER9	78.60	ER19	2355.63
ER10	174.03		



**Table 4.16** Exchangers areas of Heavy crude from PROII simulation

Exchanger	Area (m <sup>2</sup> )	Exchanger	Area (m <sup>2</sup> )
ER1	1377.43	ER9	11.85
ER2	518.49	ER10	128.83
ER3	44.61	ER11	77.63
ER4	64.78	ER12	44.10
ER5	201.95	ER13	43.84
ER6	42.86	ER14	415.66
ER7	3.93	ER15	3220.47
ER8	4.01		

**Table 4.17** Utility consumption of retrofit designs

	Light crude	Medium crude	Heavy crude
Hot utility (MJ/hr)	241069	234224	302620
Cold utility (MJ/hr)	39666	68022	136418

#### 4.2.2.3 Relocation Results

After retrofit and simulation step is complete, HEN structure changes using the existing exchangers in retrofit network is not specified. It shows where the base case exchanger are used or relocated in the retrofit case, resulting in the optimal HEN with the retrofit structure. Relocation concept is to relocate the base-case exchangers to the new location of the retrofit, with small area added or removed.

**Table 4.18** Retrofitted heat exchanger results of Light crude

Number of exchangers	Matching	Add (+) or Remove (-) areas to existing/new exchangers	Area(m <sup>2</sup> )	% Add/ Remove	Note
ER1	18-J3	E1-48.65	1169.35	-3.99	Relocation/Remove area
ER2	13-J3	E6-18.24	465.76	-3.77	Relocation/Remove area
ER3	17-J3	-	208.13	-	New Exchanger
ER4	15-J3	E9-15.82	166.18	-8.69	Relocation/Remove area
ER5	16-J3	-	137.73	-	New Exchanger
ER6	12-J3	-	160.22	-	New Exchanger
ER7	18-J2	-	24.79	-	New Exchanger
ER8	17-J2	-	16.53	-	New Exchanger
ER9	16-J2	-	12.24	-	New Exchanger
ER10	15-J2	-	13.99	-	New Exchanger
ER11	12-J2	-	15.51	-	New Exchanger
ER12	11-J2	E4-101.64	333.36	-23.37	Relocation/Remove area
ER13	12-J2	-	186.04	-	New Exchanger
ER14	16-J2	-	138.16	-	New Exchanger
ER15	17-J2	E3+38.19	113.19	50.92	Relocation/New Shell
ER16	18-J2	E7-179.39	281.61	-38.91	Relocation/Remove area
ER17	15-J1	E8-2.46	139.54	-1.74	Relocation/Remove area
ER18	11-J1	E2-167.17	867.83	-16.15	Relocation/Remove area
ER19	18-J1	-	855.32	-	New Exchanger
ER20	15-J1	E5+138.12	623.12	28.48	Relocation/New Shell
ER21	17-J1	-	832.65	-	New Exchanger

Table 4.19 Retrofitted heat exchanger results of Medium crude

Number of exchangers	Matching	Add (+) or Remove (-) areas to existing/new exchangers	Area(m <sup>2</sup> )	% Add/Remove	Note
ER1	I7-J3	E5-136.36	348.64	-28.12	Relocation/Remove area
ER2	I8-J3	E1+555.35	1773.35	45.60	Relocation/New Shell
ER3	I2-J3	-	149.86	-	New Exchanger
ER4	I6-J3	-	13.80	-	New Exchanger
ER5	I3-J3	-	254.70	-	New Exchanger
ER6	I7-J2	-	29.60	-	New Exchanger
ER7	I2-J3	E8-9.35	132.65	-6.58	Relocation/Remove area
ER8	I5-J3	-	89.01	-	New Exchanger
ER9	I6-J3	E3+3.60	78.60	4.81	Relocation/Add area
ER10	I8-J3	E9-7.97	174.03	-4.38	Relocation/Remove area
ER11	I1-J2	E4-36.42	398.58	-8.37	Relocation/Remove area
ER12	I2-J2	-	130.83	-	New Exchanger
ER13	I5-J2	-	144.67	-	New Exchanger
ER14	I8-J2	E6-41.18	442.82	-8.51	Relocation/Remove area
ER15	I1-J1	-	111.95	-	New Exchanger
ER16	I7-J1	-	165.43	-	New Exchanger
ER17	I1-J2	E7-9.50	451.50	-2.06	Relocation/Remove area
ER18	I5-J1	E2-230.43	804.57	-22.26	Relocation/Remove area
ER19	I8-J1	-	2355.63	-	New Exchanger

**Table 4.20** Retrofitted heat exchanger results of Heavy crude

Number of exchangers	Matching	Add (+) or Remove (-) areas to existing/new exchangers	Area(m <sup>2</sup> )	% Add/Remove	Note
ER1	18-J3	E1+159.43	1377.43	13.09	Relocation/Add area
ER2	12-J3	E2-516.51	518.49	-49.90	Relocation/Remove area
ER3	16-J3	-	44.61	-	New Exchanger
ER4	17-J3	E3-10.22	64.78	-13.62	Relocation/Remove area
ER5	13-J3	E9+19.95	201.95	10.96	Relocation/Add area
ER6	18-J2	-	42.86	-	New Exchanger
ER7	17-J2	-	3.93	-	New Exchanger
ER8	16-J2	-	4.01	-	New Exchanger
ER9	12-J2	-	11.85	-	New Exchanger
ER10	12-J2	E8-13.17	128.83	-9.27	Relocation/Remove area
ER11	15-J2	-	77.63	-	New Exchanger
ER12	16-J2	-	44.10	-	New Exchanger
ER13	17-J2	-	43.84	-	New Exchanger
ER14	18-J2	E4-19.34	415.66	-4.45	Relocation/Remove area
ER15	18-J1	E5+2735.47	3220.47	564.01	Relocation/New Shell

#### 4.2.2.4 Cost Evaluation Results

Net present value (NPV) is based on future cash flows for a certain number of years,  $n$ , and a specific annual interest rate. The NPV is calculated given by Equation 4.5:

$$NPV = \sum_{t=1}^{n \text{ years}} \left( \frac{\text{Utility saving cost}_i}{(1 + \text{Annual interest rate})^i} \right) - \text{Total investment cost} \quad (4.5)$$

**Table 4.21** Cost summary

	Retrofit Design		
	Light crude	Medium crude	Heavy crude
no.of new exchanger	12	10	8
Area of new exchanger	2601.31	3445.49	272.83
no. of used existing exchanger	9	9	7
Added Area	0	3.6	179.38
Removed area	533.37	471.21	559.24
no.of new shell	2	1	1
Area of new shell	176.31	555.35	2735.47
Investment cost for 5 years life time (\$)	771.578	1,042,097	1,385,774
Annualize investment cost (\$/yr)	154,316	208,419	277.155
Heating Utility (MJ/yr)	2,024,982,526	1,967,478,709	2,542,007,559
Cooling Utility (MJ/yr)	333,194,353	571,382,662	1,145,910,849
Energy saving (\$/yr)	2,976.183	3,178.105	504.822
Splitting cost (\$)	20,000	20,000	20,000
Relocation cost (\$)	25,000	25,000	25,000
NPV (\$)	10,510,498	11,005,420	527,899
Total Utility consumption (MJ/yr)	2,358,176,905	2,538,861,370	3,687,918,407

The Table 4.21 represents the cost summary. It is clear that the retrofitted design of Medium crude base has the highest NPV of 11,005,420 \$ for a 5-years lifetime and resulting in total utility saving of 35 %. Therefore the retrofitted design of Medium crude base is the optimal retrofit design processing three types of crude.